

**Golder Associates Ltd.**

#220 - 1755 Springfield Road  
Kelowna, British Columbia, Canada V1Y 5V5  
Telephone (250) 860-8424  
Fax (250) 860-9874



**REPORT ON**

**TEST WELL DRILLING AND GROUNDWATER  
DEVELOPMENT POTENTIAL EVALUATION  
CRYSTAL MOUNTAIN RESORT  
WESTBANK, BRITISH COLUMBIA**

Submitted to:

Pheidias Development Management Corporation  
Suite 1660 – 1188 West Georgia Street  
Vancouver, BC  
V6E 4A2

and

BMR Golf Construction Inc.  
2749 – 30<sup>th</sup> Street  
Vernon, BC  
V1T 5C6

**DISTRIBUTION:**

- 4 Copies - Pheidias Development Management Corp
- 1 Copy - BMR Golf Construction Inc.
- 1 Copy - Golder Associates Ltd.

April 24, 2006



04-1440-116 (20000)



## **EXECUTIVE SUMMARY**

### **INTRODUCTION**

Golder Associates Ltd. (Golder) is pleased to provide this report, summarizing the results of the construction and testing of a test well and assessment of groundwater development potential for Crystal Mountain Resort (the Resort), located approximately 14.5 km northwest of Westbank, BC. The test well (TW2) is located approximately 7.5 km to the north of the Resort, directly north of Power Creek, with the area surrounding the test well referred to as the "Study Area".

It is understood that Crystal Mountain Resort, in partnership with BMR Golf Construction Inc. (BMR Golf) is proposing to expand the current ski hill operation to include year-round resort activities, including a golf course and various accommodations (single family and multi family homes). The purpose of the construction and testing of a test well was to collect hydrogeological information to aid in the assessment of whether groundwater within the area could provide a sufficient quantity and quality of potable water to support the initial stages (Phase 1) of a proposed development within the Crystal Mountain Resort area. A preliminary estimate of the required well yield by McElhanney Consulting Services Ltd. indicated that the total water demand for Phase 1 of the development, including the golf course, is approximately 142,809 m<sup>3</sup> annually.

The scope of work for this investigation included the construction of a test well, and a 72-hour pumping test, during which time water levels were monitored within the test well and nearby observation well.

### **REGIONAL GEOLOGY AND HYDROGEOLOGY**

Based on our experience and available information, the regional surficial geology in the area of Crystal Mountain Resort consists primarily of glacial till and shallow bedrock.

TW2 is located within the northern reaches of the Powers Creek watershed, which contains numerous lakes and creeks.

## RESULTS

Based on the results of the hydrogeologic investigation and test well drilling program completed for the Study Area, the following conclusions are presented:

1. A 4 to 7 m thick, confined silty, sand and gravel aquifer has been identified in the area where TW2 has been completed, at a depth between approximately 32 and 35 m below ground surface (mbgs). The aquifer was overlain with a thick (24 m thick) clay deposit and underlain with bedrock.
2. Based on drawdown and recovery data collected during a 72-hour constant-rate pumping test, the transmissivity of the confined aquifer in which the test well is completed is approximately 8 m<sup>2</sup>/day. The hydraulic conductivity of the aquifer is estimated to be about 2 m/day.
3. The 100-day specific capacity of the well is 0.13 L/sec/m (0.6 US gpm/ft). Based on an available drawdown of 21 m (applying a 70% factor of safety), the theoretical capacity of this well is approximately 2.6 L/s (41 USgpm), the approximate rate at which the well was tested.
4. A drawdown of approximately 11 m was observed within an observation well located approximately 15 m from the pumping well. As such, it can be inferred that there will be some mutual well interference between TW2 and other potential water wells located within a 1 km radius of TW2.
5. Based on the results of the constant rate pumping test, it can be inferred that an additional pumping well located approximately 1 km from TW2 could yield an additional 2.5 L/sec (40 USgpm), with little effect of the water levels at TW2. Similarly,
  - two pumping wells located within 500 m of each other could theoretically yield approximately 2.4 L/sec (38 USgpm) each or 4.8 L/sec (76 USgpm) total; or
  - two pumping wells located within 50 m of each other in the area of TW2 could theoretically yield approximately 1.4 L/sec (23 USgpm) each, or 2.8 L/sec (46 USgpm) total.

This assumes that TW2 is one of the two wells and that the pumping rate at TW2 has been reduced to 2.4 L/sec or 1.4 L/sec, respectively.

6. Groundwater from the test well does not appear to be under the direct influence of surface water from Powers Creek at a discharge of 2.5 L/sec (40 USgpm). however, once the well is put into production and water samples collected over a suitable length of time then the water analyses should be reviewed to determine if water from the well should receive chemically assisted filtration and disinfection (or equivalent) treatment processes. .
7. Water quality testing at TW2 indicated that all analyzed parameters were below the applicable guidelines for Canadian drinking water quality (GCDWQ, CCME 1996). Hardness concentrations were reported at 196 mg/L.
8. The proposed withdrawal of approximately 2.5 L/sec (40 USgpm) is not anticipated to adversely impact surface water flows within Powers Creek or groundwater users located approximately 11 km to the southeast and hydraulically downgradient of the Study Area.

#### RECOMMENDATIONS

Based on the results of this investigation, the following recommendations are provided regarding TW2:

1. Test well TW2 is a valuable long-term asset, which should be preserved. Although the primary purpose for this test well was for identifying production and water quality options for the proposed development, the completed TW2 test well should be preserved for: a) use as a backup water supply well, capable of producing up to 2.5 L/sec (40 USgpm), b) long-term monitoring of water-levels, and c) as an observation well to monitor the aquifer and derive aquifer coefficients during hydraulic testing of potential planned production well.
2. Should the test well be used as either a backup well or an observation well, dedicated measuring tubes for housing pressure transducers and/or for manual measurement of water levels should be permanently installed in the well. A permanent pressure transducer/data logger sensor should be installed in the test well, so that an accurate and up-to-date record of water levels in the test well can be maintained by the well operator.



3. Access to the site where the test well and presumably any production wells will be located should be restricted, to discourage vandalism and animal grazing. Measures should be taken to ensure that drainage of surface water and run-off is away from the wellhead. No toxic liquids should be stored temporarily or permanently on the well lot and, preferentially, storage of these types of materials (if absolutely necessary) should be in excess of 100 m from any well head. Any wells should be enclosed in well houses, with grading sloping away from the wellheads. The well house structures should be designed to be removable so that the wells can be accessed by a drilling rig, for regular well maintenance. The wells should be secured and locked at all times to restrict access.
4. Because lateral and vertical changes in lithology can occur over very short distances, any final production well design and well screen slot sizing will be determined after the borehole of the production well is drilled. Grain size analyses of cuttings obtained from the proposed production well borehole will be necessary in order to accurately determine the final specifications of the well screen assembly. Furthermore, final recommendations on pump selection and setting depth will be made after the results of a pumping test of the production well have been evaluated.
5. Once up and running, any monitoring data from both the test well and/or proposed production wells should be periodically reviewed by a qualified professional. Typically, if the specific capacity of the well decreases by 20-to-25 percent, this is indication that a well rehabilitation program may be needed.
6. Should TW2 be used as a potable water source, consideration can be given to treating the water for hardness, if required.

The effect of pumping water from TW2 on downgradient water well users (approximately 11 km to the southeast) is considered to be negligible. However, should it be necessary, a groundwater level monitoring program could be developed for those users, such that water levels within private wells are monitored on a regular frequency. Should a monitoring program for downgradient water well users be developed, it is recommended that it be initiated as soon as possible, in order to establish some baseline data prior to the potential operation of TW2 or any other water well within the Study Area.

**TABLE OF CONTENTS**

| SECTION                                                                  | PAGE |
|--------------------------------------------------------------------------|------|
| 1.0 INTRODUCTION .....                                                   | 1    |
| 1.1 Purpose and Objective .....                                          | 1    |
| 1.2 Scope of Work .....                                                  | 1    |
| 1.3 Selection of Test Well Location .....                                | 2    |
| 2.0 REGIONAL GEOLOGY AND HYDROGEOLOGY .....                              | 2    |
| 3.0 METHODOLOGY .....                                                    | 3    |
| 3.1 Test Well Drilling .....                                             | 3    |
| 3.2 Pumping Tests.....                                                   | 5    |
| 3.3 Water Sample Collection and Chemical Analyses .....                  | 6    |
| 3.4 Well Location Surveying .....                                        | 6    |
| 4.0 RESULTS OF FIELD INVESTIGATIONS.....                                 | 6    |
| 4.1 Test Drilling and Well Construction.....                             | 6    |
| 4.1.1 TW1 .....                                                          | 6    |
| 4.1.2 TW2 .....                                                          | 7    |
| 4.2 Hydraulic Testing.....                                               | 7    |
| 4.2.1 Step-Drawdown Testing .....                                        | 7    |
| 4.2.2 Constant Rate Testing .....                                        | 8    |
| 5.0 INTERPRETATION OF RESULTS .....                                      | 8    |
| 5.1 Hydrogeological Setting .....                                        | 8    |
| 5.2 Well Capacity.....                                                   | 8    |
| 5.3 Groundwater Quality .....                                            | 10   |
| 5.4 Preliminary GUDI Assessment.....                                     | 11   |
| 5.5 Assessment of Well Interference .....                                | 13   |
| 5.6 Potential Impacts to Powers Creek and Downgradient Groundwater Users | 14   |
| 6.0 CONCLUSIONS.....                                                     | 15   |
| 7.0 RECOMMENDATIONS.....                                                 | 17   |
| 8.0 LIMITATIONS AND USE OF THIS REPORT .....                             | 18   |
| 9.0 CLOSURE .....                                                        | 20   |

**LIST OF FIGURES**

|          |                                                        |
|----------|--------------------------------------------------------|
| Figure 1 | Key Plan                                               |
| Figure 2 | Powers Creek Watershed Area                            |
| Figure 3 | Study Area and Test Well Location Plan                 |
| Figure 4 | Step Test at TW2 - Drawdown Data                       |
| Figure 5 | Well Completion Details for TW2                        |
| Figure 6 | Constant Rate Test at TW2 - Drawdown and Recovery Data |

**LIST OF TABLES**

|         |                                                                                     |
|---------|-------------------------------------------------------------------------------------|
| Table 1 | Chemical Analytical Results for TW2                                                 |
| Table 2 | Soil Profile at TW1 (in text)                                                       |
| Table 3 | Soil Profile at TW2 (in text)                                                       |
| Table 4 | Estimated Drawdowns at Various Distances from<br>Pumping Well at 100 Days (in text) |

**LIST OF APPENDICES**

|              |                                                       |
|--------------|-------------------------------------------------------|
| Appendix I   | New Well Source Construction Permit                   |
| Appendix II  | Grain Size Distribution Curves                        |
| Appendix III | Stepped-Discharge and Constant-Rate Pumping Test Data |
| Appendix IV  | Analytical Laboratory Results                         |
| Appendix V   | Drillers Well Logs                                    |
| Appendix VI  | AQTESLOV                                              |

## **1.0 INTRODUCTION**

Golder Associates Ltd. (Golder) is pleased to provide this report, summarizing the results of the construction and testing of a test well and assessment of groundwater development potential for Crystal Mountain Resort (the Resort), located approximately 14.5 km northwest of Westbank, BC (Figure 1). The test well location is located approximately 7.5 km to the north of the Resort, directly north of Power Creek, and is referred to as the "Study Area".

It is understood that Crystal Mountain Resort, in partnership with BMR Golf Construction Inc. (BMR Golf) is proposing to expand the current ski hill operation to include year-round resort activities, including a golf course and various accommodations (single family and multi family homes).

### **1.1 Purpose and Objective**

The purpose of the construction and testing of a test well was to collect hydrogeological information to aid in the assessment of whether groundwater within the area could provide a sufficient quantity and quality of potable water to support the initial stages (Phase 1) of a proposed development within the Crystal Mountain Resort area. The well yield required to support the initial stages of the proposed development is not known; however, a preliminary estimate by McElhanney Consulting Services Ltd., as outlined within their April 19, 2006 letter, indicated that the total water demand for Phase 1 of the development, including the golf course, is approximately 142,809 m<sup>3</sup> annually.

### **1.2 Scope of Work**

The scope of work for this assignment included the following:

- monitor drilling and well construction;
- collect samples of aquifer sediments and design a well screen assembly;
- design and monitor step-drawdown and constant-rate pumping tests;
- analyze pumping test data;
- collect groundwater quality sample and review results for potability; and
- prepare a hydrogeologic report, summarizing the field investigations and analyses, with conclusions and recommendations.

The structure of this report is based on the 2004 Land and Water BC (LWBC) Inc. companion document to the *Water Utility Act* and the *Utilities Commission Act* entitled "*Guide to Applying for a Certificate of Public Convenience and Necessity (CPCN)*".

### **1.3 Selection of Test Well Location**

The test well location was chosen based on

- i) the results of our August 27, 2002 letter entitled “Groundwater Availability Assessment, Proposed Crystal Mountain Resort Development, Westbank, BC”, which identified four potential well drilling locations within the Powers Creek Watershed area (Figure 2), based on precipitation recharge estimates to the areas; and
- ii) a reconnaissance of two of the four areas on October 31, 2002, which identified Area 3 as the most favourable of the four areas to construct a test well.

Two wells were drilled as part of this assignment. The first well (TW1) was drilled in December 2004, and is located approximately 60 m north of Powers Creek, and 15 m to the southeast of TW2 (Figure 3). Although this well intersected favourable subsurface soil and groundwater conditions, a subsequent break in the welded seal between casing lengths resulted in that this well could not be used to provide a potable water supply. A second test well, TW2, was drilled in close proximity to TW1, on the premise that subsurface conditions would be similar. TW2 was drilled in December 2005, and was successfully completed at a location approximately 15 m northwest of TW1 and 60 m to the north of Powers Creek (Figure 3).

## **2.0 REGIONAL GEOLOGY AND HYDROGEOLOGY**

Based on our experience and available information, the regional surficial geology in the area of Crystal Mountain Resort consists primarily of glacial till and shallow bedrock.

TW1 and TW2 are located within the northern reaches of the Powers Creek watershed, which contains numerous lakes and creeks, amongst which are Paynter Lake (located approximately 6.2 km to the northwest of the Study Area), Jackpine Lake (located approximately 5.2 km to the southwest of the Study Area), and Lambley (Bear) Lake (located approximately 1.7 km to the east of the Study Area), and Powers Creek and North Powers Creek (Figure 1). Powers Creek is located approximately 60 m to the south of the Study Area and flows in a southerly direction from Paynter Lake, eventually discharging into Okanagan Lake approximately 17.2 km to the southeast.

According to the Geological Survey of Canada, bedrock in the Study Area consists of the Cache Creek Group, which contains greenstone, quartzite, argillite and limestone.

The inferred regional direction of groundwater flow (based on topography) is southeast towards the valley bottom.

### **3.0 METHODOLOGY**

#### **3.1 Test Well Drilling**

A new well source construction permit (No. OK-157) was issued by the Interior Health Authority (“IHA”) prior to the commencement of the drilling activities (Appendix I). For the purposes of long-term monitoring and to assess the quantity and quality of groundwater, two exploratory boreholes were drilled and completed as test wells within Area 3 as described below:

##### **TW1**

TW1 was drilled by Cascade Drilling Ltd. Of Kelowna, BC in December 2004, at which time a 150 mm (6 inch) steel well casing was advanced to a total depth of 38.8 m below ground surface (mbgs), and later pulled back to a depth of approximately 32 mbgs to expose the well screen. A surface casing was not placed around this well, as this well was not useable as a water well (discussed in Section 3.2) and will likely be decommissioned.

Golder field personnel were available to monitor the first day of drilling, collecting soil samples from uniform depth intervals or at changes in the stratigraphy. Subsequent to the first day of drilling, the driller collected soil samples during drilling. The following two soil samples were selected by Golder and submitted to our in-house laboratory for grain-size analyses, to aid in the selection of an appropriate well screen.

- Sample depth – 32 mbgs
- Sample depth – 33.5 – 35 mbgs

The screen intake area (a function of well screen slot size) was chosen based on a slot size equivalent to grain size with 50% to 60% of the aquifer material being retained, as plotted on the grain size distribution plot for each sample. A conservative percent retained (50-60%) was applied during screen selection as the integrity and reliability of the samples collected were in question. Results of the grain size analyses are provided in Appendix II.

The screen assembly was installed in January 2005 and consists of two 1.2 m in length, 150 mm (6 inch) diameter, stainless steel telescopic screens. The initial screen is installed between 32 m and 33.2 m and consists of a 50 slot screen, while the second screen is installed between 33.2 m and 34.4 mbgs and consists of a 60 slot screen.

Following installation of the well screen assembly within TW1, the well was developed using the air lifting capabilities of the drilling rig. Developing of the well occurred for a period of 6.5 hours in January 2005.

## TW2

TW2 was drilled by Cyclone Drilling Ltd. of Westbank, BC, between December 19 and 20, 2005. It was drilled using a truck mounted air rotary drilling rig with a casing hammer attachment. Drilling activities for TW2 were monitored by Golder field personnel.

A 200 mm (8 inch) diameter, steel surface casing was installed to a depth of 5.5 mbgs to allow the placement of an annular bentonite grout surface seal around the outside of a 150 mm (6 inch) diameter steel casing. The 150 mm diameter steel casing was advanced through the 200 mm surface casing to a total depth of 35 mbgs. Drill cuttings returned to the surface were sampled by a Golder representative every 1.5 m (5 ft), or at noticeable changes in lithology (whichever was less). Although two soil samples were selected for grain size analyses, they did not play a role in selecting the slot size of the screens, as the screens were placed within fractured bedrock. The purpose of the screens in this instance was to prevent the sloughing of fractured rock into the borehole. The following two soil samples were selected by Golder and submitted to our in-house laboratory for grain-size analyses, the results of which are provided in Appendix II.

- Sample depth – 34.1 m – 34.7 mbgs
- Sample depth – 34.7 m – 35.4 mbgs

The screen assembly was installed on December 20, 2005, and consists of two 1.2 m in length, 150 mm (6 inch) diameter, stainless steel telescopic screens. The initial screen is installed between 34.7 m and 36.1 m and consists of a 100 slot screen, while the second screen is installed between 36.1 m and 37.5 m and consists of a 60 slot screen.

Following installation of the well screen assembly within TW2, the well was developed using the air lifting capabilities of the drilling rig. Developing of the well occurred for a period of approximately 4 hours on January 21, 2006. The well screen was developed until the water discharge was clear and relatively free of sediment.

### **3.2 Pumping Tests**

A pumping test was attempted on TW1 in January 2005 by Aqua Tech Services of Kelowna, BC. However, due to increasing silt content within the water, the test was terminated. A subsequent camera inspection within the well identified that the casing weld had broken at a depth of approximately 20 m below ground surface, allowing silt and/or clay sediment to enter into the well. As this problem could not be corrected, the well was no longer considered suitable as a water well, and was used for water level monitoring purposes during the pumping test conducted at TW2.

A pumping test was conducted on TW2 between December 27 and 31, 2005, by Aqua Tech Services Ltd. The testing consisted of a step-drawdown test to assess the specific capacity and efficiency of TW2 and to determine the optimum pumping rate to be used during the constant rate pumping test. The step drawdown test was followed by a 72-hour constant rate pumping test, and measurement of water level recovery following the cessation of pumping.

Cyclone Drilling suggested that the production well would be capable of sustaining a pumping rate of approximately 2.8 L/s (45 USgpm) to 3.2 L/s (50 USgpm). As such, the step drawdown testing was designed to consist of 4 steps, each step 90 minutes in duration, starting at 1.3 L/s (20 USgpm) for the first step, 1.9 L/s (30 USgpm) for the second step, 2.8 L/s (45 USgpm) for the third step, and 3.9 L/s (62 USgpm) for the fourth step. Based on the results of this testing, the 72-hour constant-rate pumping test was conducted at a pumping rate of 2.5 L/s (40 USgpm).

During testing, discharged water was routed away from the wellhead through 50 m of 100-mm-diameter (4-inch) PVC pipe into a forested area located approximately 50 m to the northeast of the wellhead. This area was chosen so that it would not affect the drawdown observed near TW2 during the pumping test. Precautions were taken during testing to minimize any ground erosion or flooding and to ensure there were no leaks in the discharge pipe.

Flow rates during testing were measured using an in-line digital flow meter, placed in a straight-running section of the discharge pipe at the wellhead.

Water levels within TW1 and TW2 were monitored during the testing of TW2 using data loggers installed within the wells and by collecting and recording water level measurements by hand.

Following shut down of the pump at the end of the constant-rate pumping test, the recovery to static water level was monitored in TW2 until January 1, 2006.



Water level measurement data and other observations collected during the step-drawdown and constant rate test are presented in Appendix III. A plot of the observed drawdown is shown as Figure 4.

### 3.3 Water Sample Collection and Chemical Analyses

A water sample was collected by Golder's technician from TW2 on December 29, 2005, after approximately 48 hours of pumping, to assess the potability of the groundwater adjacent to the screened portion of the aquifer. The water sample was submitted to Cantest Ltd. in Burnaby, BC for enhanced potability analyses and for radiological (Gross Alpha and Gross Beta) analyses. Analytical results are provided on Table 1 and in Appendix IV.

### 3.4 Well Location Surveying

TW1, TW2 and Powers Creek were surveyed on January 5, 2006 by Golder staff, using a total station surveying equipment, such that groundwater elevations can be compared to creek elevations.

## 4.0 RESULTS OF FIELD INVESTIGATIONS

### 4.1 Test Drilling and Well Construction

#### 4.1.1 TW1

The soil profile encountered during the drilling of TW1 is summarized in the following table. A copy of the driller's report for this well is provided in Appendix V.

**Table 2: Soil Profile at TW1**

| Soil Type       | Depth (mbgs) | Inferred Aquifer/Confining Unit | Comments      |
|-----------------|--------------|---------------------------------|---------------|
| Sand and Gravel | 0 – 1.5      | Top Soil                        | Dry           |
| Sand and Gravel | 1.5 – 4.4    | Unconfined Aquifer              | Water bearing |
| Till            | 4.4 – 15.2   | Confining Unit                  | Dry           |
| Black Clay      | 15.2 – 28.3  |                                 | Sticky        |
| Coarse Gravel   | 28.3 – 35    | Confined Aquifer                | Water bearing |
| Bedrock         | 35 – 38.7    | --                              | --            |

The depth to the static water level at the time of drilling was approximately 1.5 mbgs.

#### 4.1.2 TW2

Figure 5 shows the well completion details for TW2 and a copy of the driller's report is provided in Appendix V. The soil profile encountered during the drilling of TW2 is summarized in the following table.

**Table 3: Soil Profile at TW2**

| Soil Type                                             | Depth (mbgs) | Inferred Aquifer/Confining Unit | Comments     |
|-------------------------------------------------------|--------------|---------------------------------|--------------|
| Brown sandy clay with boulder and gravel              | 0 – 1.8      | Topsoil                         | Dry          |
| Reddish brown, coarse sand with gravel and trace clay | 1.8 – 4.6    | Unconfined Aquifer              | Wet          |
| Reddish brown sandy clay with gravel                  | 4.6 - 10.7   | Confining Unit                  | Moist to wet |
| Sandy grey clay with trace gravel                     | 10.7 – 13.4  |                                 |              |
| Silty grey clay, trace gravel at depth                | 13.4 – 31.7  |                                 | Moist to wet |
| Sand and gravel with silty sand                       | 31.7 – 34.1  | Confined Aquifer                | Wet          |
| Brown sand and gravel                                 | 34.1 – 35.1  |                                 | Wet          |
| Soft, fractured weathered bedrock                     | 35.1 – 36.9  | --                              | --           |
| Solid brown weathered bedrock                         | 36.9 – 37.5  | --                              | --           |

The maximum transmitting capacity of the screen assembly (based on recommendations of an entrance velocity of 0.03 m/s) was estimated to be 18 L/s (286 USgpm).

The available drawdown in TW2 is estimated to be 30.2 m, and is based on the difference between the static water level (1.5 mbgs) and the base of the confining layer overlying the aquifer (31.7 mbgs) in which the well screen was set.

## 4.2 Hydraulic Testing

### 4.2.1 Step-Drawdown Testing

Water level measurements that were taken during the step-drawdown testing are presented in Appendix III and a plot of drawdown versus time for the four steps is presented in Figure 4. The plot shows that the individual drawdowns resulting from each step are as follows: 5.6 m after the first step, followed by 3.9 m after the second step, 6 m after the third step and the final drawdown after the fourth step was 7.3 m. Based on the results of the step-drawdown test, a rate of 2.5 L/s (40 USgpm) was selected for the 72-hour constant rate pumping test.

#### 4.2.2 Constant Rate Testing

The constant-rate pumping test was conducted at 2.5 L/s (40 USgpm) for a 72-hour period. Water level measurements were recorded at TW1 and TW2 during the constant-rate pumping test, the results of which are presented in Appendix III and in Figure 6. The total drawdown observed within TW2 during the pumping test was 16.8 m after 72 hours of pumping, while the total drawdown noted at TW1 was approximately 11.8 m.

Upon cessation of pumping, water levels at TW1 and TW2 recovered to within 90% of the pre-test static water level within 24 hours.

### 5.0 INTERPRETATION OF RESULTS

#### 5.1 Hydrogeological Setting

Based on the results of the test well drilling program, a shallow, unconfined sand and gravel aquifer is present in the area of TW1 and TW2, between approximately 1.5 m and 4.6 mbgs. This is underlain with a 24 m to 27 m thick confining deposit of clay. A confined sand and gravel aquifer appears to be present below the confining deposit to a depth of approximately 35 mbgs, and is underlain with bedrock. The lateral extent of the aquifer is unknown, as information in the area is limited. However, the saturated thickness of the confined aquifer is approximately 4 m to 7 m, and is based on the distance between the bedrock surface and the base of the confining deposit.

The results of the well and creek elevation survey indicated that groundwater elevations at TW1 and TW2 are approximately 4 m higher than the creek elevation in the area, thus implying there is an upward hydraulic gradient within the confined aquifer. However, there is insufficient information to assess the direction of groundwater flow within the deeper, confined aquifer. Based on the topography of the area, it can be inferred that the groundwater flow in the area of TW2 is towards the southeast.

#### 5.2 Well Capacity

Well capacity was estimated using the methodology outlined in the guidance document published by the BCMoE entitled "*Evaluating Long-Term Well Capacity for a Certificate of Public Convenience and Necessity (CPCN)*" (1999). The recommended methodology for estimating the well capacity typically calls for a minimum 72-hour duration pumping test during low water level periods (late fall-winter for the interior of B.C). The MoE recommends that the following four criteria be considered when evaluating well capacity:

1. adequate pumping test procedures;
2. estimated drawdown in pumping well extended to a minimum of 100 day period;
3. total available drawdown in the pumping well; and,
4. other factors, such as well design limitations, well interference and water quality.

The theoretical well capacity (Q) for a specific well, using information from the well log and the pumping test, is calculated as follows:

$$Q = 0.7 \text{ (70\% of the available drawdown)} \times 100 \text{ day specific capacity} \times \text{total available drawdown in the pumping well}$$

The 100 day specific capacity is estimated by projecting the drawdown of the 72-hour pumping test to 100 days. The 100 day projection period is utilized as it extends the pumping period from the mid-winter period (Dec/Jan) when the lowest static water levels typically exist to April/May when recharge typically occurs to an aquifer from spring snowmelt/runoff. This time period is intended to represent the period when the recharge to the aquifer is the lowest and hence reasonable worst case conditions.

As shown on Figure 6, the extrapolated drawdown after 100 days of pumping at a discharge of approximately 2.5 L/sec (40 USgpm) is approximately 20.5 m. This is slightly less than the total available drawdown at TW2 of 21 m, applying a 70% factor of safety.

The 100-day specific capacity of the well is 0.13 L/sec/m (0.6 US gpm/ft). Based on an available drawdown of 21 m (applying a 70% factor of safety), the theoretical capacity of this well is approximately 2.7 L/s (43 USgpm), the approximate rate at which the well was tested.

The characteristics of the confined aquifer were estimated using the results of the constant rate pumping test and AQTESOLV<sup>TM</sup>, a commercial software package for pumping test analysis. The transmissivity of the aquifer was estimated using the Leaky Hantush solution method, a type curve solution for a pumping/recovery test in a leaky, confined aquifer. Transmissivity is the rate at which groundwater is transmitted through a unit width of an aquifer under a unit hydraulic gradient. The transmissivity was estimated to be approximately 8 m<sup>2</sup>/day. Copies of the output file and a plot of the solution generated using the AQTESOLV<sup>TM</sup> program are included in Appendix VI.

The hydraulic conductivity of the aquifer was estimated to be in the order of approximately 2 m/day, based on the calculated transmissivity of 8 m<sup>2</sup>/day and the approximate 4 m saturated thickness of the aquifer encountered in the immediate area of the test well. For comparative purposes, the hydraulic conductivity of sediments also can be estimated from grain size distribution curves, providing the uniformity coefficient and density of the material are known (Driscoll, 1986). Without the benefit of blow counts or laboratory analysis to determine density, the density of the aquifer sediments was estimated to be “medium-dense”, based on the effort of driving the steel casing through the aquifer section. The uniformity coefficient is determined by dividing the “90% passing” grain size by the “40% passing” grain size, obtained from the grain size distribution curves of the drilled aquifer sediments (Appendix II). Using a uniformity coefficient of 10 for medium-dense sediments, the hydraulic conductivity of the aquifer sediments (represented by the 50% passing grain size), is approximately 26 m/day, which is one order of magnitude greater than the hydraulic conductivity based on the transmissivity value.

Specific storage for the aquifer was also estimated using AQTESOLV™, and was estimated to be approximately 0.00006. This specific storage value is typical of confined aquifers (Driscoll, 1986).

### 5.3 Groundwater Quality

Results of laboratory analysis indicate the water samples collected from TW2 near the end of the constant-rate pumping test meet the *Guidelines for Canadian Drinking Water Quality* (GCDWQ) for all analyzed parameters. The water quality results are summarized in Table 1, along with the maximum acceptable concentrations (MACs), interim maximum acceptable concentrations (IMACs), and aesthetic objectives (AOs) guidelines, where applicable. While MACs and IMACs are health-based standards, AOs are based on aesthetic water quality and typically are not a health concern. Note that hardness is an aesthetic objective, with public acceptance of hardness varying considerably. Generally hardness levels between 80 mg/L and 100 mg/L are considered acceptable, with levels greater than 200 mg/L considered poor, and levels greater than 500 mg/L considered unacceptable. Hardness concentrations at TW2 were reported to be 196 mg/L. With the exception of the water being slightly hard, groundwater from TW2 is of good, potable quality for drinking water and other needs.

The water sample collected from TW2 was also submitted for the analyses of radiological parameters. The results of the analyses for gross alpha and gross beta were reported to be 0.11 (+/- 0.06) Becquerel/litre (Bq/L) and 0.38 (+/- 0.06) Bq/L, respectively. According to the GCDWQ, compliance with the guidelines can be inferred provided that gross alpha measurements are less than 0.1 Bq/L and that gross beta concentrations are below 1 Bq/L, as these MACs represent the most conservative MACs for the listed radio nuclides.

However, it is possible for the gross alpha and/or gross beta results to exceed the 0.1 and 1 Bq/L guideline, and still be below the GCDWQ for the individual radionuclide parameters.

The gross beta results for TW2 are well below the guidelines, however, the gross alpha results were slightly greater than the most conservative guideline for gross alpha parameters. As such, Golder requested that the two specific radionuclide parameters (Lead-210 and Thorium-232) be analyzed, as the MAC for these radio nuclides are 0.1 Bq/L. The next highest MAC is for Thorium-230 at a MAC of 0.4 Bq/L. The results of this analyses indicated that Lead-210 and Thorium-232 concentrations were 0.02 and 0.01, respectively (Appendix IV). As such, it can be inferred that all gross alpha concentrations are below the MACs listed in the GCDWQ.

#### **5.4 Preliminary GUDI Assessment**

The Province of British Columbia does not have a formal regulation with respect to evaluating if groundwater is considered to be under the direct influence of surface water ("GUDI"). As such, the Ontario Ministry of Environment (MOE) protocols were followed as outlined in the Ministry document entitled "Terms of Reference for Hydrogeological Study to Examine Groundwater Sources Potentially Under Direct Influence of Surface Water" dated October 2001. The document states that community wells are "flagged" as potentially under the direct influence of surface water if they satisfy the following criteria:

- The wells regularly contain Total Coliforms and/or periodically contain E. coli; or
- The wells are located within approximately 50 days horizontal saturated travel time from surface water, or are within 100 m (overburden wells) or 500 m (bedrock wells) of surface water (whichever is greater) **and** meet one or more of the following criteria:
  - o Wells may be drawing water from an unconfined aquifer;
  - o Wells may be drawing water from formations within approximately 15 m of surface;
  - o Wells are part of an enhanced recharge/infiltration project;
  - o When the well is pumped, water levels in surface water rapidly change or hydraulic gradients beside the surface water significantly increase in a downward direction;

- o Chemical water quality parameters are more consistent with nearby surface water than local groundwater and/or if they fluctuate significantly and rapidly in response to climatological or surface water conditions.

A GUDI designation would require that the water from the well receive chemically assisted filtration and disinfection (or equivalent treatment processes).

There is insufficient water quality information to assess whether TW2 can be “flagged” as GUDI; however, based on the presently available physical and chemical information it is our opinion that the well would not be flagged as GUDI. The following provides comments on the presently available physical and chemical information:

1. There is insufficient chemical monitoring data to assess if the well *regularly* contains total coliforms and/or periodically contains E. Coli. However, the initial chemical analyses of a water sample collected from TW2 indicated that total and fecal coliform concentrations were below the laboratory detection limit of 1 colony per 100 mL.
2. TW2 is located within 100 m of surface water (overburden well).
3. TW2 does not appear to be collecting water from an unconfined aquifer or from within 15 m of the surface.
4. Water level measurements of Powers Creek during the pumping test did not appear to be impacted as a result of the 72-hour pumping test. In addition, groundwater levels within TW2 during the test did not indicate the presence of a positive boundary condition (Powers Creek).
5. The quality of the surface water within Powers Creek was not evaluated.

Notwithstanding the above, once the well is placed in production and water samples are collected over a sufficient period of time, then a full evaluation of whether the well should be “flagged” as GUDI should be made.

## 5.5 Assessment of Well Interference

As previously stated, water levels were monitored in an observation well (TW1) during the constant rate pumping test of TW2. TW1 is located approximately 15 m to the southeast of TW2. As shown on Figure 6, the rate at which water levels were lowered during the pumping test was similar within TW1 as TW2. The total drawdown within TW1 was approximately 11.8 m after approximately 72 hours of pumping at a rate of approximately 2.5 L/sec (40 USgpm). Extrapolating the drawdown to 100 days, the anticipated drawdown at TW1 was approximately 16 mbgs.

Based on observations at TW1, and using AQTESOLV™ Golder was able to assess the potential for well interference should another pumping well be constructed within the area. As a preliminary assessment, AQTESOLV's leaky Hantush solution for confined aquifers was used to predict the extent of the drawdown at a potential well location 500 m and 1000 m away from TW2. Based on a transmissivity of 8 m<sup>2</sup>/day and a specific storage value of approximately 0.00006, the following table summarizes the estimated drawdowns approximately 100 days after pumping, at various distances from the pumping well.

**Table 4: Estimated Drawdowns at Various Distances from Pumping Well at 100 Days**

| <b>Drawdown at TW2 (pumping well)</b> | <b>Drawdown at 15 m away (TW1)</b> | <b>Drawdown at 50 m away</b> | <b>Drawdown at 500 m away</b> | <b>Drawdown at 1000 m away</b> |
|---------------------------------------|------------------------------------|------------------------------|-------------------------------|--------------------------------|
| 20.5 m                                | 15.5 m                             | 10 m                         | 2 m                           | 0.5 m                          |

This prediction involved several basic assumptions about the hydraulic conditions in the aquifer. Among them are the following:

- The aquifer is bounded above and below by top and bottom by a confining layers;
- All geologic formations are horizontal and of relatively large horizontal extent; and
- The aquifer is relatively homogeneous and isotropic; and

Based on our knowledge of the hydrogeologic conditions at the site, these assumptions appear to be reasonable.



Based on the above, the estimated theoretical drawdown approximately 1 km away from TW2 is approximately 0.5 m. Alternatively, it can be inferred that a well located approximately 1 km away from TW2 would induce approximately 0.5 m of drawdown at TW2, assuming similar aquifer conditions and pumping rates as TW2. This would potentially result in the water level at TW2 dropping to approximately 21 mbgs (the total available drawdown at a period of 100 days).

Drawdown from mutual well interference at any subsequent wells drilled in the area should not exceed 70 % of the available drawdown at that well. Based on the above Table 4, an additional pumping well located approximately 1 km from TW2 could yield an additional 2.5 L/sec (40 USgpm) without dropping water levels within TW2 below 70% of the available drawdown. Similarly, an additional pumping well located approximately 500 m away from TW2 would potentially result in an additional 2 m drop in water levels within TW2. To ensure that the water level at TW2 would not fall below 21 m (70% of the available drawdown), the yield at TW2 would be required to be reduced to approximately 2.4 L/sec (38 USgpm). Thus combined yields with TW2 pumping and an additional well pumping approximately 500 m away would be in the order of 4.8 L/sec (76 USgpm). Similarly, an additional pumping well be constructed approximately 50 m away from TW2, this would potentially result in an additional 10 m drop in water levels within TW2. As this would result in the water level falling below the 70% of available drawdown, the pumping rate at TW2 would be required to be reduced to 1.4 L/sec (23 USgpm), to accommodate the resulting drop in water levels. Two wells pumping within 50 m of each other could theoretically yield approximately 1.4 L/sec (23 USgpm) each, or 2.8 L/sec (46 USgpm) total.

## **5.6 Potential Impacts to Powers Creek and Downgradient Groundwater Users**

It is understood that the Westbank Irrigation District (“WID”) has expressed some concern regarding the proposed use of groundwater collected from the area of Powers Creek, as Powers Creek provides potable and irrigation water for the WID. WID is concerned that the close location of TW2 to Powers Creek would result in reduced flows to the creek and removal of potentially licensed surface water.

According to the WID’s Capital Works Plan (Agua Consulting Inc., 2005), the average annual runoff flows within Powers Creek are estimated to be approximately 920 L/sec, with projected flows under drought conditions estimated to be approximately 410 L/sec. The withdrawal of approximately 2.5 L/sec of *groundwater* for the proposed development only accounts for approximately 0.3% of the total average annual runoff flows, and 0.6% of runoff flows during drought conditions within Powers Creek.

Based on the following, it is our opinion that i) flows within Powers Creek will not be adversely affected by the proposed withdrawal of approximately 2.5 L/sec (40 USgpm) of groundwater for the proposed development and ii) groundwater collected from the area of TW2 does not represent licensed surface water:

- Based on the location of Powers Creek approximately 60 m to the south of TW2, it can be inferred that the 24 m thick confining deposits encountered at TW1 and TW2 extend beneath Powers Creek. The upper portion of the confining deposit was identified as unsaturated in the drillers' logs. The presence of these confining deposits substantially reduces the infiltration of creek water to the local groundwater regime, thus inferring that Powers Creek and groundwater from the deeper confined aquifer are not likely hydraulically connected in the area of TW2.
- The results of the well and creek elevation survey indicated that groundwater elevations at TW1 and TW2 are approximately 4 m higher than the creek elevation in the area, thus implying there is an upward hydraulic gradient within the confined aquifer.
- Based on the results of the pumping test, no positive boundary condition, indicating the presence of a hydraulic connection with a water body, was identified during the constant rate pumping test, as water levels within TW2 did not stabilize, nor did the rate at which the water levels were dropping decrease. Thus, it can be inferred that Powers Creek is not recharging groundwater within the area of TW2.

In addition, there has also been some concern from residents in the Westbank area who collect their water from springs and groundwater wells, that the water requirements of the proposed development would reduce the water yields within their wells/springs. The nearest private water wells to the Study Area are located approximately 11 km to the southeast. As shown in the above analyses the interference effects in these wells would be negligible.

## **6.0 CONCLUSIONS**

Based on the results of the hydrogeologic investigation and test well drilling program completed for the Study Area, the following conclusions are presented:

1. A 4 to 7 m thick, confined silty, sand and gravel aquifer has been identified in the area where TW2 has been completed, at a depth between approximately 32 and 35 mbgs. The aquifer was overlain with a thick (24 m thick) clay deposit and underlain with bedrock.

2. Based on drawdown and recovery data collected during a 72-hour constant-rate pumping test, the transmissivity of the confined aquifer in which the test well is completed is approximately  $8 \text{ m}^2/\text{day}$ . The hydraulic conductivity of the aquifer is estimated to be about  $2 \text{ m/day}$ .
3. The 100-day specific capacity of the well is  $0.13 \text{ L/sec/m}$  ( $0.6 \text{ US gpm/ft}$ ). Based on an available drawdown of  $21 \text{ m}$  (applying a 70% factor of safety), the theoretical capacity of this well is approximately  $2.6 \text{ L/s}$  ( $41 \text{ USgpm}$ ), the approximate rate at which the well was tested.
4. A drawdown of approximately  $11 \text{ m}$  was observed within an observation well located approximately  $15 \text{ m}$  from the pumping well. As such, it can be inferred that there will be some mutual well interference between TW2 and other potential water wells located within a  $1 \text{ km}$  radius of TW2.
5. Based on the results of the constant rate pumping test, it can be inferred that an additional pumping well located approximately  $1 \text{ km}$  from TW2 could yield an additional  $2.5 \text{ L/sec}$  ( $40 \text{ USgpm}$ ), with little effect of the water levels at TW2. Similarly,
  - two pumping wells located within  $500 \text{ m}$  of each other could theoretically yield approximately  $2.4 \text{ L/sec}$  ( $38 \text{ USgpm}$ ) each or  $4.8 \text{ L/sec}$  ( $76 \text{ USgpm}$ ) total; or
  - two pumping wells located within  $50 \text{ m}$  of each other in the area of TW2 could theoretically yield approximately  $1.4 \text{ L/sec}$  ( $23 \text{ USgpm}$ ) each, or  $2.8 \text{ L/sec}$  ( $46 \text{ USgpm}$ ) total.

This assumes that TW2 is one of the two wells and that the pumping rate at TW2 has been reduced to  $2.4 \text{ L/sec}$  or  $1.4 \text{ L/sec}$ , respectively.

6. Groundwater from the test well does not appear to be under the direct influence of surface water from Powers Creek at a discharge of  $2.5 \text{ L/sec}$  ( $40 \text{ USgpm}$ ). however, once the well is put into production and water samples collected over a suitable length of time then the water analyses should be reviewed to determine if water from the well should receive chemically assisted filtration and disinfection (or equivalent) treatment processes. .
7. Water quality testing at TW2 indicated that all analyzed parameters were below the applicable guidelines for Canadian drinking water quality (GCDWQ, CCME 1996). Hardness concentrations were reported at  $196 \text{ mg/L}$ .

8. The proposed withdrawal of approximately 2.5 L/sec (40 USgpm) is not anticipated to adversely impact surface water flows within Powers Creek or groundwater users located approximately 11 km to the southeast and hydraulically downgradient of the Study Area.

## **7.0 RECOMMENDATIONS**

Based on the results of this investigation, the following recommendations are provided regarding TW2:

1. Test well TW2 is a valuable long-term asset, which should be preserved. Although the primary purpose for this test well was for identifying production and water quality options for the proposed development, the completed TW2 test well should be preserved for: a) use as a backup water supply well, capable of producing up to 2.5 L/sec (40 USgpm), b) long-term monitoring of water-levels, and c) as an observation well to monitor the aquifer and derive aquifer coefficients during hydraulic testing of potential planned production well.
2. Should the test well be used as either a backup well or an observation well, dedicated measuring tubes for housing pressure transducers and/or for manual measurement of water levels should be permanently installed in the well. A permanent pressure transducer/data logger sensor should be installed in the test well, so that an accurate, and up-to-date record of water levels in the test well can be maintained by the well operator.
3. Access to the site where the test well and presumably any production wells will be located should be restricted, to discourage vandalism and animal grazing. Measures should be taken to ensure that drainage of surface water and run-off is away from the wellhead. No toxic liquids should be stored temporarily or permanently on the well lot and, preferentially, storage of these types of materials (if absolutely necessary) should be in excess of 100 m from any well head. Any wells should be enclosed in well houses, with grading sloping away from the wellheads. The well house structures should be designed to be removable so that the wells can be accessed by a drilling rig, for regular well maintenance. The wells should be secured and locked at all times to restrict access.

4. Because lateral and vertical changes in lithology can occur over very short distances, any final production well design and well screen slot sizing will be determined after the borehole of the production well is drilled. Grain size analyses of cuttings obtained from the proposed production well borehole will be necessary in order to accurately determine the final specifications of the well screen assembly. Furthermore, final recommendations on pump selection and setting depth will be made after the results of a pumping test of the production well have been evaluated.
5. Once up and running, any monitoring data from both the test well and/or proposed production wells should be periodically reviewed by a qualified professional. Typically, if the specific capacity of the well decreases by 20-to-25 percent, this is indication that a well rehabilitation program may be needed.
6. Should TW2 be used as a potable water source, consideration can be given to treating the water for hardness, if required.

The effect of pumping water from TW2 on downgradient water well users (approximately 11 km to the southeast) is considered to be negligible. However, should it be necessary, a groundwater level monitoring program could be developed for those users, such that water levels within private wells are monitored on a regular frequency. Should a monitoring program for downgradient water well users be developed, it is recommended that it be initiated as soon as possible, in order to establish some baseline data prior to the potential operation of TW2 or any other water well within the Study Area.

## **8.0 LIMITATIONS AND USE OF THIS REPORT**

This report was prepared for the exclusive use of Pheidias Development Management Corporation, BMR Construction Inc. and their representatives and is intended to provide documentation of the test well drilling program and a preliminary assessment of groundwater production potential from a proposed production well to be completed at this location. This report is not meant to represent a legal opinion regarding compliance with applicable laws. Any use which a third party makes of this letter report, or any reliance on, or decisions to be made based on it, are the responsibilities of such third parties. Golder accepts no responsibility for damages, if any, suffered by any third party as a result of decisions made or actions taken based on this letter report.

The assessment of groundwater conditions presented has been made using historical and technical data collected and information from sources noted in the report. The methodologies used to conduct field investigation, to analyze information and for the preparation of a technical report were performed according to current professional standards and practices in the groundwater field.

Calculations of long-term well capacity have been made based on well conditions at the time when pumping tests have been completed. Typically, for public water supply wells in British Columbia, pumping tests are completed for a minimum duration of 72 hours in accordance with the guidance document entitled "*Evaluating Long-Term Well Capacity for a Certificate of Public Convenience and Necessity (CPCN)*". For other well types, including those for domestic, agricultural and industrial use, the duration of testing is a function of aquifer type and hydrogeological setting, as well as observed response during testing and hydrogeological judgment.

The actual drawdown measured in a well will depend on well design, pumping rate, and well efficiency in addition to aquifer hydraulics. It is typical for wells to realize decreasing efficiency over time due to precipitation of dissolved chemicals or sedimentation in the well. Periodic maintenance of wells may alleviate these problems. Golder makes no prediction concerning the effect of decreasing well efficiency on well yields. Furthermore, any chemical analysis, based on either sampling completed as part of field investigations on this assignment, or on water quality information provided by others, is intended to provide a snapshot only of the existing water quality available from the aquifer and only at the locations specified. The spatial and temporal water quality within the aquifer may vary as the aquifer is stressed or impacts occur due to other influences.

Predictions regarding potential impacts are based on a reasonably good understanding of the current conditions at the Site. However because of the limited available data, in particular information on fundamental aquifer characteristics including aquifer transmissivity, width and thickness, some uncertainty exists with respect to predictions


Golder has relied in good faith on information provided by third parties noted in this report. We accept no responsibility for any deficiency, misstatements or inaccuracies contained in this report as a result of omissions, misinterpretations or fraudulent acts of others. Furthermore, if new information is discovered during future work, including excavations, borings or other studies, Golder should be requested to provide amendments as required.

## 9.0 CLOSURE

We trust the foregoing provides the information you need at this time. Should you have any questions or require additional information, please do not hesitate to contact the undersigned.

Yours truly,

**GOLDER ASSOCIATES LTD.**



Jacqueline Foley, M.Sc.  
Hydrogeologist



Don Chorley, M.Sc., P.Eng.  
Senior Hydrogeologist, Associate

Attachments

JF/WZ/DC/jc

N:\Active\2004\1440 - Kelowna\04-1440-116 Crystal Mountain Phase 1 PST\Task 2000 New Water Supply\Final\GW Eval letter April 24-06.doc

## REFERENCES

AQTESOLV<sup>®</sup> for Windows<sup>®</sup> 95/98/NT/2000/XP version 3.50 Professional. Developed by Glenn Duffield, HydroSOLVE, Inc. © ARCADIS Geraghty & Miller, Inc. 1996-2003.

British Columbia Ministry of Environment (2004) “Groundwater Protection Regulation”, under the BC Water Act. BC Reg 299/2004.

British Columbia, Ministry of Environment “Evaluating Long-Term Well Capacity for a Certificate of Public Convenience and Necessity”.

Driscoll, F.G. 1986. Groundwater and Wells. Johnson Filtration Systems. 1089 p.

Geological Survey of Canada (1970) Department of Energy Mines and Resources. “*Structure and Petrology of the Grand Forks Group, British Columbia*”. Page 69-22.

Health Canada. (1996) Guidelines for Canadian Drinking Water Quality. Sixth Ed.

Ontario Ministry of Environment (2001) *Protocol for Delineation of Wellhead Protection Areas for Municipal Groundwater Supply Wells Under Direct Influence of Surface Water*. A Guideline Document for the Ontario Drinking Water Protection Regulation. 5 pages

Ontario Ministry of Environment (2001). *Terms of Reference – Hydrogeological Study to Examine Groundwater Sources Potentially Under Direct Influence of Surface Water*. A Guideline Document for the Ontario Drinking Water Protection Regulation. 6 pages

Wei, M., et al (2000) *Well Protection Toolkit*. Co-published by Ministry of Environment, Land and Parks, Ministry of Health and Ministry Responsible for Seniors. Six separate booklets with examples.




## **FIGURES AND TABLES**



Image:82E13.png

Apr 03, 2006 - 9:57am

N:\Active\Year 2004\440\041-440116\Drafting\ Drawing file: K440116-01.dwg



# REFERENCE

NTS 1:50,000 Map 82E13, "Peachland" Dated,

PROJECT

CRYSTAL MOUNTAIN RESORT,  
BMR GOLF CONSTRUCTION INC.  
PHEIDIAS DEVELOPMENT MANAGEMENT CORP.  
GROUDWATER EVALUATION, WESTBANK, B.C.

TITLE

## KEY PLAN



**Golder Associates**  
Abbotsford, BC


|             |                 |
|-------------|-----------------|
| PROJECT No. | 04-1440-116     |
| DESIGN      | J.F. 09/03/06   |
| CADD        | S.S.S. 09/03/06 |
| CHECK       |                 |
| REVIEW      |                 |

|          |            |
|----------|------------|
| FILE No. | K440116-01 |
| SCALE    | AS SHOWN   |
| REV.     | 0          |

**FIGURE 1**



Image:82E13.png Image:82L04.png




**LEGEND**

 Potential Well Drilling Locations from 2002 Investigation


**REFERENCE**


NTS 1:50,000 Map 82E13, "Peachland" Dated,




|                                                                                       |             |                                                                                                                                                                                                                                                                                                                                                                            |                |             |             |          |                |        |      |          |                |      |        |          |        |       |  |  |  |        |  |  |  |
|---------------------------------------------------------------------------------------|-------------|----------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------------|----------------|-------------|-------------|----------|----------------|--------|------|----------|----------------|------|--------|----------|--------|-------|--|--|--|--------|--|--|--|
| PROJECT                                                                               |             | CRYSTAL MOUNTAIN RESORT,<br>BMR GOLF CONSTRUCTION INC.,<br>PHEIDIAS DEVELOPMENT MANAGEMENT CORP.<br>GROUDWATER EVALUATION, WESTBANK, B.C.                                                                                                                                                                                                                                  |                |             |             |          |                |        |      |          |                |      |        |          |        |       |  |  |  |        |  |  |  |
| TITLE                                                                                 |             | <b>POWERS CREEK WATERSHED AREA</b>                                                                                                                                                                                                                                                                                                                                         |                |             |             |          |                |        |      |          |                |      |        |          |        |       |  |  |  |        |  |  |  |
|  |             | <table border="1"><tr><td>PROJECT No.</td><td>04-1440-116</td><td>FILE No.</td><td>P440116-02.DWG</td></tr><tr><td>DESIGN</td><td>J.F.</td><td>10/03/06</td><td>SCALE AS SHOWN</td></tr><tr><td>CADD</td><td>S.S.S.</td><td>10/03/06</td><td>REV. 0</td></tr><tr><td>CHECK</td><td></td><td></td><td></td></tr><tr><td>REVIEW</td><td></td><td></td><td></td></tr></table> |                | PROJECT No. | 04-1440-116 | FILE No. | P440116-02.DWG | DESIGN | J.F. | 10/03/06 | SCALE AS SHOWN | CADD | S.S.S. | 10/03/06 | REV. 0 | CHECK |  |  |  | REVIEW |  |  |  |
| PROJECT No.                                                                           | 04-1440-116 | FILE No.                                                                                                                                                                                                                                                                                                                                                                   | P440116-02.DWG |             |             |          |                |        |      |          |                |      |        |          |        |       |  |  |  |        |  |  |  |
| DESIGN                                                                                | J.F.        | 10/03/06                                                                                                                                                                                                                                                                                                                                                                   | SCALE AS SHOWN |             |             |          |                |        |      |          |                |      |        |          |        |       |  |  |  |        |  |  |  |
| CADD                                                                                  | S.S.S.      | 10/03/06                                                                                                                                                                                                                                                                                                                                                                   | REV. 0         |             |             |          |                |        |      |          |                |      |        |          |        |       |  |  |  |        |  |  |  |
| CHECK                                                                                 |             |                                                                                                                                                                                                                                                                                                                                                                            |                |             |             |          |                |        |      |          |                |      |        |          |        |       |  |  |  |        |  |  |  |
| REVIEW                                                                                |             |                                                                                                                                                                                                                                                                                                                                                                            |                |             |             |          |                |        |      |          |                |      |        |          |        |       |  |  |  |        |  |  |  |
|                                                                                       |             | <b>FIGURE 2</b>                                                                                                                                                                                                                                                                                                                                                            |                |             |             |          |                |        |      |          |                |      |        |          |        |       |  |  |  |        |  |  |  |







|                                                                                       |  |                                                                                                                                            |        |                            |                |
|---------------------------------------------------------------------------------------|--|--------------------------------------------------------------------------------------------------------------------------------------------|--------|----------------------------|----------------|
| PROJECT                                                                               |  | CRYSTAL MOUNTAIN RESORT,<br>BMR GOLF CONSTRUCTION INC.,<br>PHEIDIAS DEVELOPMENT MANAGEMENT CORP.<br>GROUNDWATER EVALUATION, WESTBANK, B.C. |        |                            |                |
| TITLE                                                                                 |  | STEP TEST AT TW2                                                                                                                           |        |                            |                |
|  |  | PROJECT No. 04-1440-065                                                                                                                    |        | FILE No. Tw2 Step Test.cdr |                |
|                                                                                       |  | DESIGN                                                                                                                                     | J.F.   | 13/03/06                   | SCALE AS SHOWN |
|                                                                                       |  | CADD                                                                                                                                       | S.S.S. | 13/03/06                   | REV.           |
|                                                                                       |  | CHECK                                                                                                                                      |        |                            |                |
|                                                                                       |  | REVIEW                                                                                                                                     |        |                            |                |
|                                                                                       |  |                                                                                                                                            |        |                            | FIGURE 4       |



NOTE: (1) All measurements taken from top of casing



SCALE NTS  
DATE 24/APR/06  
DESIGN JF  
CADD JG

TITLE

## WELL COMPLETION DETAIL FOR TW#2

FILE No. 041440116\_2000\_5.dwg

CHECK


PROJECT No. 04-1440-116(2000) REV. 0

REVIEW

CRYSTAL MT. RESORT

FIGURE

5



|                                                                                       |  |                                                                                                                                            |             |          |                |
|---------------------------------------------------------------------------------------|--|--------------------------------------------------------------------------------------------------------------------------------------------|-------------|----------|----------------|
| PROJECT                                                                               |  | CRYSTAL MOUNTAIN RESORT,<br>BMR GOLF CONSTRUCTION INC.,<br>PHEIDIAS DEVELOPMENT MANAGEMENT CORP.<br>GROUNDWATER EVALUATION, WESTBANK, B.C. |             |          |                |
| TITLE                                                                                 |  | CONSTANT RATE TEST AT TW2                                                                                                                  |             |          |                |
|  |  | PROJECT No.                                                                                                                                | 04-1440-065 | FILE No. | Constant.cdr   |
|                                                                                       |  | DESIGN                                                                                                                                     | J.F.        | 13/03/06 | SCALE AS SHOWN |
|                                                                                       |  | CADD                                                                                                                                       | S.S.S.      | 13/03/06 | REV.           |
|                                                                                       |  | CHECK                                                                                                                                      |             |          |                |
|                                                                                       |  | REVIEW                                                                                                                                     |             |          |                |
| FIGURE 6                                                                              |  |                                                                                                                                            |             |          |                |

**Table 1 - Drinking Water Analytical Results**  
**TW2, Crystal Mt. Resort, Westbank, B.C.**

| Parameter                               | Sample ID           | TW2              | CDWQ <sup>1</sup> |                    |
|-----------------------------------------|---------------------|------------------|-------------------|--------------------|
|                                         | Date Sampled        |                  | AO                | MAC/ IMAC          |
| Units                                   |                     |                  |                   |                    |
| <b>Conventional Parameters</b>          |                     |                  |                   |                    |
| pH                                      | (-)                 | 7.61             | 6.5 - 8.5         | -                  |
| Conductivity                            | uS/cm               | 373              | -                 | -                  |
| True Color                              | CU                  | <5               | 15                | -                  |
| Turbidity                               | NTU                 | 0.26             | 5                 | 1                  |
| Hardness CaCO <sub>3</sub>              | mg/L                | 196              | - <sup>2</sup>    | -                  |
| Total Dissolved Solids                  | mg/L                | 240              | 500               | -                  |
| Bicarbonate Alkalinity HCO <sub>3</sub> | mg/L                | 205              | -                 | -                  |
| Carbonate Alkalinity CO <sub>3</sub>    | mg/L                | <0.5             | -                 | -                  |
| Hydroxide Alkalinity OH                 | mg/L                | <0.5             | -                 | -                  |
| Dissolved Fluoride F                    | mg/L                | 0.11             | -                 | 1.5                |
| Dissolved Chloride Cl                   | mg/L                | 0.66             | 250               | -                  |
| Nitrate and Nitrite N                   | mg/L                | 0.27             | -                 | 10                 |
| Dissolved Nitrate N                     | mg/L                | 0.27             | -                 | 45                 |
| Nitrite N                               | mg/L                | <0.002           | -                 | 3.2                |
| Dissolved Sulphate SO <sub>4</sub>      | mg/L                | 21.4             | 500               | -                  |
| <b>Total Metals</b>                     |                     |                  |                   |                    |
| Aluminum Al                             | mg/L                | 0.014            | -                 | 0.1                |
| Antimony Sb                             | mg/L                | <0.001           | -                 | 0.006              |
| Arsenic As                              | mg/L                | <0.001           | -                 | 0.005 <sup>3</sup> |
| Barium Ba                               | mg/L                | 0.029            | -                 | 1                  |
| Boron B                                 | mg/L                | <0.05            | -                 | 5                  |
| Cadmium Cd                              | mg/L                | 0.0004           | -                 | 0.005              |
| Chromium Cr                             | mg/L                | <0.001           | -                 | 0.05               |
| Copper Cu                               | mg/L                | 0.006            | 1.0               | -                  |
| Iron Fe                                 | mg/L                | <0.05            | 0.3               | -                  |
| Lead Pb                                 | mg/L                | 0.002            | -                 | 0.010              |
| Magnesium Mg                            | mg/L                | 4.8              | -                 | -                  |
| Manganese Mn                            | mg/L                | 0.002            | 0.05              | -                  |
| Mercury                                 | mg/L                | <0.00002         | -                 | 0.001              |
| Selenium Se                             | mg/L                | 0.001            | -                 | 0.01               |
| Uranium U                               | mg/L                | 0.0009           | -                 | 0.02               |
| Zinc Zn                                 | mg/L                | 0.01             | 5                 | -                  |
| <b>Dissolved Metals</b>                 |                     |                  |                   |                    |
| Calcium Ca                              | mg/L                | 70.4             | -                 | -                  |
| Iron Fe                                 | mg/L                | <0.05            | 0.3               | -                  |
| Magnesium Mg                            | mg/L                | 4.92             | -                 | -                  |
| Manganese Mn                            | mg/L                | 0.002            | 0.05              | -                  |
| Potassium K                             | mg/L                | 2.8              | -                 | -                  |
| Silicon SiO <sub>2</sub>                | mg/L                | 9.3              | -                 | -                  |
| Sodium Na                               | mg/L                | 3.68             | 200               | -                  |
| <b>Microbiological Analysis</b>         |                     |                  |                   |                    |
| Total Coliform (Confirmed)              | Col./100 mL         | <1               | -                 | not detected       |
| Fecal Coliform                          | Col./100 mL         | <1               | -                 | not detected       |
| <b>Radionuclides</b>                    |                     |                  |                   |                    |
| Gross Alpha                             | Bq/L <sup>6,7</sup> | <b>0.11+0.05</b> | -                 | 0.1                |
| Gross Beta                              | Bq/L                | 0.38+0.06        | -                 | 1                  |

- Health Canada. 1996 (and all amendments as posted on the internet at time of report). Guidelines for Canadian Drinking Water Quality (CDWQ). (April 2004)  
 AO = Aesthetic Objective  
 MAC = Maximum Acceptable Concentration  
 IMAC = Interim Maximum Acceptable Concentration
- Hardness is an aesthetic objective, with public acceptance of hardness varying considerably. Generally, hardness levels between 80 and 100 mg/L are considered acceptable, with levels greater than 200 mg/L considered poor and level greater than 500 mg/L considered unacceptable.
- Value is a proposed CDWQ guideline and is more conservative than the current MAC guideline of 0.025 mg/L.
- Boxed and bold values indicates concentration exceeds the CDWQ guideline, i.e., 

|            |
|------------|
| <b>100</b> |
|------------|
- Boxed value indicates concentration approaching the CDWQ guideline, i.e., 

|     |
|-----|
| 100 |
|-----|
- Bq/L = Bequerels per litre
- Subsequent analyses indicated that Gross Alpha concentrations were below MAC, as individual radionuclide parameters with MAC less than 0.4 Bq/L resulted in concentrations below 0.1 Bq/L (Appendix IV).



## **Appendix I**

### **New Well Source Construction Permit**

December 19, 2005

W – Crystal Mountain Resorts

Crystal Mountain Resorts Ltd.  
PO Box 26044  
Westbank, BC V4T 2G3**FAXED**  
DEC. 19/05

Dear Sir:

**Re: Attached Construction Permit No. OK-157 Crystal Mountain Resorts**

Enclosed is a Construction Permit issued under Section 7 of the *Drinking Water Protection Act* authorizing your new well source construction. This Permit is valid for one year only and is non-transferable. Any changes to the approved well must receive pre-construction authorization in writing from the undersigned.

The well must be completed according to the *Ground Water Protection Regulation* [http://www.qp.gov.bc.ca/statreg/reg/W/Water/Water299\\_2004/299\\_2004.htm](http://www.qp.gov.bc.ca/statreg/reg/W/Water/Water299_2004/299_2004.htm) and Part 5 of the *Water Act* [http://www.qp.gov.bc.ca/statreg/stat/W/96483\\_01.htm](http://www.qp.gov.bc.ca/statreg/stat/W/96483_01.htm). A letter of Certification from the hydrogeologist stating that the production well was constructed in accordance with the *Ground Water Protection Regulation* and Part 5 of the *Water Act* should be submitted.

Once the production well has been drilled and pump tested, please provide this office with the driller's log, bacteriological and chemical analysis of a water sample, letter of certification and hydrogeologist report, so that the well may be approved as a community water source.

A separate construction permit will be required to complete the production well and connect it to the water supply system. (See attached "Guidelines for the Approval of Waterworks")

Should the well prove insufficient or inadequate and require that the well be closed, the closure of the well must be done in accordance with Section 6, Appendix A of the *Ground Water Protection Regulation*.

Yours truly,

Wayne Radomske, E.I.T.  
Public Health Engineering  
Okanagan Service Delivery Area

WAR:hl

Encl.

C.C. PHI, IHA, 2<sup>nd</sup> Floor, 1340 Ellis Street, Kelowna, BC V1Y 9N1  
Water Use Planning & Utilities Branch, Ministry Of Environment, Water Stewardship Division  
Management Standards Branch, Po Box 9340 Stn Prov Govt, Victoria Bc V8W 9M1  
**Golder Associates**, Suite 220 - 1755 Springfield Road, Kelowna, BC V1Y 5V5

c.c. PHI, IHA, Kelowna  
MOE Utilities Branch  
Golder Associates

W – Crystal Mountain Resorts



Interior Health

# Waterworks Construction Permit

NO. OK – 157


**TO CRYSTAL MOUNTAIN RESORTS**

**THIS IS TO CERTIFY THAT** the application form dated December 8, 2005 and the site plan Figure 1 portraying Project No. 012-4063 prepared by Golder Associates, showing the proposed location of the well at Crystal Mountain Resorts, Westbank, B.C., and submitted in accordance with Section 7 of the *Drinking Water Protection Act* have been reviewed and the proposed work on the construction, alteration or extension may be commenced in accordance with the approved plan.

*This document certifies that the plans and specifications for the proposed works have been reviewed pursuant to the current "Waterworks System Guidelines" issued by Interior Health and that the plans and specifications meet the health protection requirements outlined in the Guidelines.*

*The Standards of structural adequacy and safety of the works have not been considered and are not the subject of this Permit.*


December 19, 2005  
DATE ISSUED

  
ISSUING OFFICIAL

## **Appendix II**


### **Grain Size Distribution Curves**

Grain Size Analysis



|          |         |        |        |      |        |        |      |        |        |      |      |
|----------|---------|--------|--------|------|--------|--------|------|--------|--------|------|------|
| Boulders | Cobbles | Coarse | Medium | Fine | Coarse | Medium | Fine | Coarse | Medium | Fine | Clay |
|          |         | Gravel |        |      | Sand   |        |      | Silt   |        |      |      |

Grain Size Analysis





## **Appendix III**

### **Stepped-Discharge and Constant-Rate Pumping Test Data**

## **Step-Discharge Test**

| Step-Drawdown Test          | Date       | Time     | Time since pump started, t (minutes) | Time since pump stopped, t' (minutes) | Step-Drawdown Test of Production Well TW2 |                                    |                           |              |                             |                      |
|-----------------------------|------------|----------|--------------------------------------|---------------------------------------|-------------------------------------------|------------------------------------|---------------------------|--------------|-----------------------------|----------------------|
|                             |            |          |                                      |                                       | t/t'                                      | Water level measurement (btoc) (m) | Water level change, s (m) | Drawdown (m) | Residual Drawdown (s' in m) | Pumping Rate (USgpm) |
| Step-Drawdown Test No. 1    | 27/12/2005 | 12:00:00 | 0                                    | --                                    | --                                        | 2.03                               | -                         | 0.00         | --                          | 20                   |
|                             |            | 12:01:00 | 1                                    | --                                    | --                                        | 4.30                               | 2.27                      | 2.27         | --                          |                      |
|                             |            | 12:02:00 | 2                                    | --                                    | --                                        | 4.80                               | 0.50                      | 2.77         | --                          |                      |
|                             |            | 12:03:00 | 3                                    | --                                    | --                                        | 5.09                               | 0.29                      | 3.07         | --                          |                      |
|                             |            | 12:04:00 | 4                                    | --                                    | --                                        | 5.27                               | 0.18                      | 3.25         | --                          |                      |
|                             |            | 12:05:00 | 5                                    | --                                    | --                                        | 5.41                               | 0.13                      | 3.38         | --                          |                      |
|                             |            | 12:06:00 | 6                                    | --                                    | --                                        | 5.53                               | 0.12                      | 3.50         | --                          |                      |
|                             |            | 12:07:00 | 7                                    | --                                    | --                                        | 5.66                               | 0.13                      | 3.64         | --                          |                      |
|                             |            | 12:08:00 | 8                                    | --                                    | --                                        | 5.74                               | 0.08                      | 3.71         | --                          |                      |
|                             |            | 12:09:00 | 9                                    | --                                    | --                                        | 5.81                               | 0.07                      | 3.78         | --                          |                      |
|                             |            | 12:10:00 | 10                                   | --                                    | --                                        | 5.88                               | 0.08                      | 3.86         | --                          |                      |
|                             |            | 12:12:00 | 12                                   | --                                    | --                                        | 5.99                               | 0.11                      | 3.96         | --                          |                      |
|                             |            | 12:14:00 | 14                                   | --                                    | --                                        | 6.13                               | 0.14                      | 4.10         | --                          |                      |
|                             |            | 12:16:00 | 16                                   | --                                    | --                                        | 6.21                               | 0.08                      | 4.18         | --                          |                      |
|                             |            | 12:18:00 | 18                                   | --                                    | --                                        | 6.28                               | 0.08                      | 4.25         | --                          |                      |
|                             |            | 12:20:00 | 20                                   | --                                    | --                                        | 6.36                               | 0.07                      | 4.33         | --                          |                      |
|                             |            | 12:25:00 | 25                                   | --                                    | --                                        | 6.55                               | 0.20                      | 4.52         | --                          |                      |
|                             |            | 12:30:00 | 30                                   | --                                    | --                                        | 6.68                               | 0.13                      | 4.65         | --                          |                      |
|                             |            | 12:35:00 | 35                                   | --                                    | --                                        | 6.80                               | 0.12                      | 4.77         | --                          |                      |
|                             |            | 12:40:00 | 40                                   | --                                    | --                                        | 6.92                               | 0.12                      | 4.89         | --                          |                      |
|                             |            | 12:45:00 | 45                                   | --                                    | --                                        | 7.02                               | 0.10                      | 5.00         | --                          |                      |
| Step-Drawdown Test No. 2    | 27/12/2005 | 12:50:00 | 50                                   | --                                    | --                                        | 7.10                               | 0.08                      | 5.07         | --                          | 30                   |
|                             |            | 12:55:00 | 55                                   | --                                    | --                                        | 7.20                               | 0.10                      | 5.17         | --                          |                      |
|                             |            | 13:00:00 | 60                                   | --                                    | --                                        | 7.28                               | 0.08                      | 5.25         | --                          |                      |
|                             |            | 13:10:00 | 70                                   | --                                    | --                                        | 7.44                               | 0.16                      | 5.41         | --                          |                      |
|                             |            | 13:20:00 | 80                                   | --                                    | --                                        | 7.56                               | 0.12                      | 5.53         | --                          |                      |
|                             |            | 13:30:00 | 90                                   | --                                    | --                                        | 7.67                               | 0.11                      | 5.64         | --                          |                      |
|                             |            | 13:31:00 | 91                                   | --                                    | --                                        | 8.90                               | 1.23                      | 6.87         | --                          |                      |
|                             |            | 13:32:00 | 92                                   | --                                    | --                                        | 9.30                               | 0.40                      | 7.27         | --                          |                      |
|                             |            | 13:33:00 | 93                                   | --                                    | --                                        | 9.47                               | 0.17                      | 7.44         | --                          |                      |
|                             |            | 13:34:00 | 94                                   | --                                    | --                                        | 9.60                               | 0.13                      | 7.57         | --                          |                      |
|                             |            | 13:35:00 | 95                                   | --                                    | --                                        | 9.70                               | 0.10                      | 7.67         | --                          |                      |
|                             |            | 13:36:00 | 96                                   | --                                    | --                                        | 9.77                               | 0.07                      | 7.74         | --                          |                      |
|                             |            | 13:37:00 | 97                                   | --                                    | --                                        | 9.83                               | 0.06                      | 7.80         | --                          |                      |
|                             |            | 13:38:00 | 98                                   | --                                    | --                                        | 9.88                               | 0.05                      | 7.85         | --                          |                      |
|                             |            | 13:39:00 | 99                                   | --                                    | --                                        | 9.93                               | 0.05                      | 7.90         | --                          |                      |
|                             |            | 13:40:00 | 100                                  | --                                    | --                                        | 9.98                               | 0.05                      | 7.95         | --                          |                      |
|                             |            | 13:42:00 | 102                                  | --                                    | --                                        | 10.05                              | 0.07                      | 8.02         | --                          |                      |
|                             |            | 13:44:00 | 104                                  | --                                    | --                                        | 10.14                              | 0.09                      | 8.11         | --                          |                      |
|                             |            | 13:46:00 | 106                                  | --                                    | --                                        | 10.19                              | 0.05                      | 8.16         | --                          |                      |
|                             |            | 13:48:00 | 108                                  | --                                    | --                                        | 10.28                              | 0.09                      | 8.25         | --                          |                      |
|                             |            | 13:50:00 | 110                                  | --                                    | --                                        | 10.33                              | 0.05                      | 8.30         | --                          |                      |
|                             |            | 13:55:00 | 115                                  | --                                    | --                                        | 10.47                              | 0.13                      | 8.44         | --                          |                      |
|                             |            | 14:00:00 | 120                                  | --                                    | --                                        | 10.61                              | 0.14                      | 8.58         | --                          |                      |
|                             |            | 14:05:00 | 125                                  | --                                    | --                                        | 10.71                              | 0.10                      | 8.68         | --                          |                      |
|                             |            | 14:10:00 | 130                                  | --                                    | --                                        | 10.80                              | 0.09                      | 8.77         | --                          |                      |
|                             |            | 14:15:00 | 135                                  | --                                    | --                                        | 10.90                              | 0.09                      | 8.87         | --                          |                      |
|                             |            | 14:20:00 | 140                                  | --                                    | --                                        | 10.98                              | 0.09                      | 8.96         | --                          |                      |
|                             |            | 14:25:00 | 145                                  | --                                    | --                                        | 11.08                              | 0.09                      | 9.05         | --                          |                      |
|                             |            | 14:30:00 | 150                                  | --                                    | --                                        | 11.15                              | 0.07                      | 9.12         | --                          |                      |
|                             |            | 14:40:00 | 160                                  | --                                    | --                                        | 11.27                              | 0.12                      | 9.24         | --                          |                      |
|                             |            | 14:50:00 | 170                                  | --                                    | --                                        | 11.40                              | 0.13                      | 9.37         | --                          |                      |
|                             |            | 15:00:00 | 180                                  | --                                    | --                                        | 11.52                              | 0.12                      | 9.49         | --                          |                      |
| Step-Drawdown Test No. 3    | 27/12/2005 | 15:01:00 | 181                                  | --                                    | --                                        | 13.54                              | 2.02                      | 11.51        | --                          | 45                   |
|                             |            | 15:02:00 | 182                                  | --                                    | --                                        | 14.11                              | 0.57                      | 12.08        | --                          |                      |
|                             |            | 15:03:00 | 183                                  | --                                    | --                                        | 14.52                              | 0.41                      | 12.49        | --                          |                      |
|                             |            | 15:04:00 | 184                                  | --                                    | --                                        | 14.75                              | 0.23                      | 12.72        | --                          |                      |
|                             |            | 15:05:00 | 185                                  | --                                    | --                                        | 14.92                              | 0.17                      | 12.89        | --                          |                      |
|                             |            | 15:06:00 | 186                                  | --                                    | --                                        | 15.05                              | 0.12                      | 13.02        | --                          |                      |
|                             |            | 15:07:00 | 187                                  | --                                    | --                                        | 15.16                              | 0.12                      | 13.14        | --                          |                      |
|                             |            | 15:08:00 | 188                                  | --                                    | --                                        | 15.24                              | 0.08                      | 13.21        | --                          |                      |
|                             |            | 15:09:00 | 189                                  | --                                    | --                                        | 15.31                              | 0.07                      | 13.29        | --                          |                      |
|                             |            | 15:10:00 | 190                                  | --                                    | --                                        | 15.39                              | 0.07                      | 13.36        | --                          |                      |
|                             |            | 15:12:00 | 192                                  | --                                    | --                                        | 15.52                              | 0.14                      | 13.50        | --                          |                      |
|                             |            | 15:14:00 | 194                                  | --                                    | --                                        | 15.64                              | 0.11                      | 13.61        | --                          |                      |
|                             |            | 15:16:00 | 196                                  | --                                    | --                                        | 15.73                              | 0.10                      | 13.71        | --                          |                      |
|                             |            | 15:18:00 | 198                                  | --                                    | --                                        | 15.83                              | 0.09                      | 13.80        | --                          |                      |
|                             |            | 15:20:00 | 200                                  | --                                    | --                                        | 15.91                              | 0.08                      | 13.88        | --                          |                      |
|                             |            | 15:25:00 | 205                                  | --                                    | --                                        | 16.09                              | 0.19                      | 14.06        | --                          |                      |
|                             |            | 15:30:00 | 210                                  | --                                    | --                                        | 16.27                              | 0.17                      | 14.24        | --                          |                      |
|                             |            | 15:35:00 | 215                                  | --                                    | --                                        | 16.39                              | 0.13                      | 14.36        | --                          |                      |
|                             |            | 15:40:00 | 220                                  | --                                    | --                                        | 16.55                              | 0.16                      | 14.53        | --                          |                      |
|                             |            | 15:45:00 | 225                                  | --                                    | --                                        | 16.70                              | 0.14                      | 14.67        | --                          |                      |
|                             |            | 15:50:00 | 230                                  | --                                    | --                                        | 16.84                              | 0.14                      | 14.81        | --                          |                      |
|                             |            | 15:55:00 | 235                                  | --                                    | --                                        | 16.91                              | 0.08                      | 14.89        | --                          |                      |
|                             |            | 16:00:00 | 240                                  | --                                    | --                                        | 16.99                              | 0.08                      | 14.96        | --                          |                      |
|                             |            | 16:10:00 | 250                                  | --                                    | --                                        | 17.17                              | 0.18                      | 15.14        | --                          |                      |
|                             |            | 16:20:00 | 260                                  | --                                    | --                                        | 17.31                              | 0.14                      | 15.28        | --                          |                      |
|                             |            | 16:30:00 | 270                                  | --                                    | --                                        | 17.48                              | 0.17                      | 15.45        | --                          |                      |
| Step-Drawdown Test No. 4    | 27/12/2005 | 16:31:00 | 271                                  | --                                    | --                                        | 20.15                              | 2.68                      | 18.12        | --                          | 62 to 64             |
|                             |            | 16:32:00 | 272                                  | --                                    | --                                        | 21.41                              | 1.25                      | 19.38        | --                          |                      |
|                             |            | 16:33:00 | 273                                  | --                                    | --                                        | 21.91                              | 0.50                      | 19.88        | --                          |                      |
|                             |            | 16:34:00 | 274                                  | --                                    | --                                        | 22.26                              | 0.35                      | 20.23        | --                          |                      |
|                             |            | 16:35:00 | 275                                  | --                                    | --                                        | 22.46                              | 0.21                      | 20.43        | --                          |                      |
|                             |            | 16:36:00 | 276                                  | --                                    | --                                        | 22.61                              | 0.15                      | 20.58        | --                          |                      |
|                             |            | 16:37:00 | 277                                  | --                                    | --                                        | 22.74                              | 0.13                      | 20.71        | --                          |                      |
|                             |            | 16:38:00 | 278                                  | --                                    | --                                        | 22.84                              | 0.10                      | 20.81        | --                          |                      |
|                             |            | 16:39:00 | 279                                  | --                                    | --                                        | 22.91                              | 0.08                      | 20.89        | --                          |                      |
|                             |            | 16:40:00 | 280                                  | --                                    | --                                        | 22.99                              | 0.07                      | 20.96        | --                          |                      |
|                             |            | 16:42:00 | 282                                  | --                                    | --                                        | 23.12                              | 0.13                      | 21.09        | --                          |                      |
|                             |            | 16:44:00 | 284                                  | --                                    | --                                        | 23.24                              | 0.12                      | 21.21        | --                          |                      |
|                             |            | 16:46:00 | 286                                  | --                                    | --                                        | 23.38                              | 0.14                      | 21.35        | --                          |                      |
|                             |            | 16:48:00 | 288                                  | --                                    | --                                        | 23.43                              | 0.05                      | 21.40        | --                          |                      |
|                             |            | 16:50:00 | 290                                  | --                                    | --                                        | 23.51                              | 0.09                      | 21.48        | --                          |                      |
|                             |            | 16:55:00 | 295                                  | --                                    | --                                        | 23.69                              | 0.18                      | 21.66        | --                          |                      |
|                             |            | 17:00:00 | 300                                  | --                                    | --                                        | 23.84                              | 0.15                      | 21.81        | --                          |                      |
|                             |            | 17:05:00 | 305                                  | --                                    | --                                        | 23.97                              | 0.14                      | 21.94        | --                          |                      |
|                             |            | 17:10:00 | 310                                  | --                                    | --                                        | 24.09                              | 0.11                      | 22.06        | --                          |                      |
|                             |            | 17:15:00 | 315                                  | --                                    | --                                        | 24.19                              | 0.11                      | 22.16        | --                          |                      |
|                             |            | 17:20:00 | 320                                  | --                                    | --                                        | 24.30                              | 0.10                      | 22.27        | --                          |                      |
|                             |            | 17:25:00 | 325                                  | --                                    | --                                        | 24.37                              | 0.07                      | 22.34        | --                          |                      |
|                             |            | 17:30:00 | 330                                  | --                                    | --                                        | 24.46                              | 0.09                      | 22.43        | --                          |                      |
|                             |            | 17:40:00 | 340                                  | --                                    | --                                        | 24.61                              | 0.15                      | 22.58        | --                          |                      |
|                             |            | 17:50:00 | 350                                  | --                                    | --                                        | 24.72                              | 0.11                      | 22.69        | --                          |                      |
|                             |            | 18:00:00 | 360                                  | --                                    | --                                        | 24.83                              | 0.11                      | 22.80        | --                          |                      |
| End of Step Test (Recovery) | 27/12/2005 | 18:00:30 | 360.5                                | 0.5                                   | 721                                       | 19.73                              | -5.10                     | 17.70        | 0.00                        | --                   |
|                             |            | 18:01:00 | 361                                  | 1                                     | 361                                       | 16.11                              | -3.61                     | 14.08        | 3.61                        | --                   |
|                             |            | 18:02:00 | 362                                  | 2                                     | 181                                       | 13.52                              | -2.60                     | 11.49        | 6.21                        | --                   |
|                             |            | 18:03:00 | 363                                  | 3                                     | 121                                       | 12.35                              | -1.17                     | 10.32        | 7.38                        | --                   |
|                             |            | 18:04:00 | 364                                  | 4                                     | 91                                        | 11.65                              | -0.70                     | 9.62         | 8.08                        | --                   |

## **Constant Rate Pumping Test**

## **Appendix IV**

### **Analytical Laboratory Results**

## **Cantest Results**

## Analysis Report



CANTEST LTD.

Professional  
Analytical  
Services

4606 Canada Way  
Burnaby, B.C.  
V5G 1K5

Fax: 604 731 2386

Tel: 604 734 7276

1 800 665 8566

**REPORT ON:** Analysis of Water Samples

**REPORTED TO:** Golder Associates Ltd.  
220-1755 Springfield Rd  
Kelowna, BC  
V1Y 5V5

Att'n: J. Foley

**CHAIN OF CUSTODY:** 186308  
**PROJECT NAME:** Crystal Mtn.  
**PROJECT NUMBER:** 04-1440-116

---

**NUMBER OF SAMPLES:** 1

**REPORT DATE:** February 22, 2006

**DATE SUBMITTED:** December 30, 2005

**GROUP NUMBER:** 61230016

**SAMPLE TYPE:** Water

**NOTE:** Results contained in this report refer only to the testing of samples as submitted. Other information is available on request.

### TEST METHODS:

**Anions in Water by Ion Chromatography** - was determined based on Method 4110 in Standard Methods (20th Edition) and EPA Method 300.0 (Revision 2.1).

**Alkalinity in Water** - was performed based on Method 2320 in Standard Methods (20th Edition).

**Alkalinity in Water** - was performed based on Method 2320 in Standard Methods (20th Edition).

**Colour (True) in Water** - was determined based on Method 2120 in Standard Methods (20th Edition) and Method X321 in the BC Laboratory Manual (1994 Edition).

**Conductivity in Water** - was performed based on Method 2510 in Standard Methods and Method X322 in the BC Laboratory Manual (1994 Edition).

**Hardness in Water** - was calculated based on Method 2340 B in Standard Methods for the Examination of Water and Wastewater (20th Edition, 1998).

**Nitrite in Water** - was determined based on Method 4500-NO<sub>3</sub> B in Standard Methods for the examination of Water and Wastewater (20th Edition) and from the BC Laboratory Methods Manual (2003 Edition).

**pH in Water** - was determined based on Method 4500-H in Standard Methods (20th Edition) and Method X330 in the BC Laboratory Manual (1994 Edition).

(Continued)

CANTEST LTD.

Tim Matsushita  
Coordinator, Water Laboratory

Page 1 of 6





**REPORTED TO:** Golder Associates Ltd.



**REPORT DATE:** February 22, 2006

**GROUP NUMBER:** 61230016

---

**Total Dissolved Solids in Water** - was determined based on Method 2540 C in Standard Methods (20th Edition).

**Turbidity in Water** - was performed based on Method 2130 in Standard Methods (20th Edition) and Method X164 in the BC Laboratory Manual (1994 Edition).

**Conventional Parameters** - analyses were performed using procedures based on those described in "British Columbia Environmental Laboratory Manual For the Analysis of Water, Wastewater, Sediment and Biological Materials" (1994 Edition), Province of British Columbia and "Standard Methods for the Examination of Water and Wastewater" 20th Edition, (1998), published by the American Public Health Association.

**Mercury in Water** - analysis was performed using procedures based on U. S. EPA Method 1631, oxidative digestion using bromination, and analysis using Cold Vapour Atomic Fluorescence Spectroscopy.

**Metals in Water** - analysis was performed using Inductively Coupled Plasma Optical Emission Spectroscopy (ICP), Inductively Coupled Plasma-Mass Spectroscopy (ICP/MS).

**Field Filtered Metals in Water** - Samples were filtered in the field (e.g. at the time of sampling) and quantitatively determined using Inductively Coupled Plasma Optical Emission Spectroscopy (ICP) and/or Inductively Coupled Plasma-Mass Spectroscopy (ICP/MS).

**Microbiological Parameters** - analyses were performed using procedures based on those described in "B. C. Environmental Laboratory Manual For the Analysis of Water, Wastewater, Sediment and Biological Materials" (1994 Edition) and "Standard Methods for the Examination of Water and Wastewater", 20th Edition (1998). Analysis was performed using Membrane Filtration (MF) Method (reported as "Colonies or CFU per unit volume").

**Gross Alpha and Gross Beta** - analysis was performed using a Tennelec LB5100 Analyzer. This test was performed by a subcontractor.

#### **COMMENTS:**

Amended Report-This report supercedes the original hard copy dated January 25, 2006. The Canadian Drinking Water Guidelines have been removed as per Jacque Foley of Golder Associates (Kelowna).

#### **TEST RESULTS:**

(See following pages)



REPORTED TO: Golder Associates Ltd.



REPORT DATE: February 22, 2006

GROUP NUMBER: 61230016

Conventional Parameters in Water

|                               |                   |                 |                 |            |
|-------------------------------|-------------------|-----------------|-----------------|------------|
| CLIENT SAMPLE IDENTIFICATION: |                   | Crystal Mtn TW2 |                 |            |
| DATE SAMPLED:                 |                   | Dec 29/05       |                 |            |
| CANTEST ID:                   |                   | 512300033       |                 |            |
|                               |                   |                 | DETECTION LIMIT | UNITS      |
| pH, Laboratory                |                   | 7.61            | -               | pH units   |
| Conductivity                  |                   | 373             | 1               | $\mu$ S/cm |
| True Color                    |                   | <               | 5               | CU         |
| Turbidity                     |                   | 0.26            | 0.1             | NTU        |
| Hardness                      | CaCO <sub>3</sub> | 196             | 1               | mg/L       |
| Total Dissolved Solids        |                   | 240             | 10              | mg/L       |
| Total Alkalinity              | CaCO <sub>3</sub> | 168             | 0.5             | mg/L       |
| Bicarbonate Alkalinity        | HCO <sub>3</sub>  | 205             | 0.5             | mg/L       |
| Carbonate Alkalinity          | CO <sub>3</sub>   | <               | 0.5             | mg/L       |
| Hydroxide Alkalinity          | OH                | <               | 0.5             | mg/L       |
| Dissolved Fluoride            | F                 | 0.11            | 0.05            | mg/L       |
| Dissolved Chloride            | Cl                | 0.66            | 0.2             | mg/L       |
| Nitrate and Nitrite           | N                 | 0.27            | 0.05            | mg/L       |
| Dissolved Nitrate             | N                 | 0.27            | 0.05            | mg/L       |
| Nitrite                       | N                 | <               | 0.002           | mg/L       |
| Dissolved Sulphate            | SO <sub>4</sub>   | 21.4            | 0.5             | mg/L       |

$\mu$ S/cm = microsiemens per centimeter

NTU = nephelometric turbidity units

< = Less than detection limit

CU = color units

mg/L = milligrams per liter



REPORTED TO: Golder Associates Ltd.



REPORT DATE: February 22, 2006

GROUP NUMBER: 61230016

Metals Analysis in Water

| CLIENT SAMPLE IDENTIFICATION: |    | Crystal Mtn TW2 | Crystal Mtn TW2 | DETECTION LIMIT | UNITS |
|-------------------------------|----|-----------------|-----------------|-----------------|-------|
| SAMPLE PREPARATION:           |    | TOTAL           | DISSOLVED       |                 |       |
| DATE SAMPLED:                 |    | Dec 29/05       | Dec 29/05       | DETECTION LIMIT | UNITS |
| CANTEST ID:                   |    | 512300033       | 512300033       |                 |       |
| Aluminum                      | Al | 0.014           | -               | 0.005           | mg/L  |
| Antimony                      | Sb | <               | -               | 0.001           | mg/L  |
| Arsenic                       | As | <               | -               | 0.001           | mg/L  |
| Barium                        | Ba | 0.029           | -               | 0.001           | mg/L  |
| Boron                         | B  | <               | -               | 0.05            | mg/L  |
| Cadmium                       | Cd | 0.0004          | -               | 0.0002          | mg/L  |
| Calcium                       | Ca | -               | 70.4            | 0.05            | mg/L  |
| Chromium                      | Cr | <               | -               | 0.001           | mg/L  |
| Copper                        | Cu | 0.006           | -               | 0.001           | mg/L  |
| Iron                          | Fe | <               | <               | 0.05            | mg/L  |
| Lead                          | Pb | 0.002           | -               | 0.001           | mg/L  |
| Magnesium                     | Mg | 4.80            | 4.92            | 0.05            | mg/L  |
| Manganese                     | Mn | 0.002           | 0.002           | 0.001           | mg/L  |
| Mercury                       | Hg | <               | -               | 0.02            | µg/L  |
| Potassium                     | K  | -               | 2.8             | 0.1             | mg/L  |
| Selenium                      | Se | 0.001           | -               | 0.001           | mg/L  |
| Silicon                       | Si | -               | 9.3             | 0.25            | mg/L  |
| Sodium                        | Na | -               | 3.68            | 0.05            | mg/L  |
| Uranium                       | U  | 0.0009          | -               | 0.0005          | mg/L  |
| Zinc                          | Zn | 0.010           | -               | 0.005           | mg/L  |

mg/L = milligrams per liter

µg/L = micrograms per liter

< = Less than detection limit



REPORTED TO: Golder Associates Ltd.



REPORT DATE: February 22, 2006

GROUP NUMBER: 61230016

---

**Radionuclides in Water**

| CLIENT SAMPLE IDENTIFICATION: | SAMPLE DATE | CANTEST ID | Gross Alpha  | Gross Beta   |
|-------------------------------|-------------|------------|--------------|--------------|
| Crystal Mtn TW2               | Dec 29/05   | 512300033  | 0.11 + -0.05 | 0.38 + -0.06 |
| DETECTION LIMIT UNITS         |             |            | 0.04 Bq/L    | 0.05 Bq/L    |

Bq/L = Bequerels per liter



REPORTED TO: Golder Associates Ltd.



REPORT DATE: February 22, 2006

GROUP NUMBER: 61230016

---

**Microbiological Analysis in Water**

| CLIENT SAMPLE IDENTIFICATION: | SAMPLE DATE | CANTEST ID | Total Coliforms (Confirmed) | Fecal Coliform |
|-------------------------------|-------------|------------|-----------------------------|----------------|
| Crystal Mtn TW2               | Dec 29/05   | 512300033  | <                           | <              |
| DETECTION LIMIT UNITS         |             |            | 1 Col./100 mL               | 1 Col./100 mL  |

Col./100 mL = Colonies per 100 mL

< = Less than detection limit



REPORTED TO: Golder Associates Ltd.



REPORT DATE: February 22, 2006

GROUP NUMBER: 61230016

Batch Quality Control for Conventional Parameters in Water

| Parameter              |                   | QC Type                       | QC Result | Units      | Lower Limit | Upper Limit |
|------------------------|-------------------|-------------------------------|-----------|------------|-------------|-------------|
| pH, Laboratory         |                   | pH Calibration Verification   | 98.1      | % Recovery | 98          | 102         |
|                        |                   | Duplicate                     | 0.1       | R.P.D.     | 0           | 3           |
|                        |                   | Duplicate                     | 0.3       | R.P.D.     | 0           | 3           |
| Conductivity           |                   | Blank                         | 1         | uS/cm      | 0           | 1           |
|                        |                   | Conductivity Calibration Ver. | 102.0     | % Recovery | 96          | 104         |
|                        |                   | Duplicate                     | 0.5       | R.P.D.     | 0           | 5           |
|                        |                   | Duplicate                     | 0.9       | R.P.D.     | 0           | 5           |
| True Color             |                   | Blank                         | < 5       | CU         | 0           | 5           |
|                        |                   | Calibration Verification      | 87.5      | % Recovery | 75          | 105         |
|                        |                   | Duplicate                     | 0.0       | R.P.D.     | 0           | 10          |
| Turbidity              |                   | Blank                         | < 0.1     | NTU        | 0           | 0.1         |
|                        |                   | Duplicate                     | 0.0       | R.P.D.     | 0           | 15          |
|                        |                   | Duplicate                     | 0.0       | R.P.D.     | 0           | 15          |
|                        |                   | Duplicate                     | 1.2       | R.P.D.     | 0           | 15          |
| Total Dissolved Solids |                   | Duplicate                     | 5.6       | R.P.D.     | 0           | 18          |
| Total Alkalinity       | CaCO <sub>3</sub> | Blank                         | 2.9       | mg/L       | 0           | 4           |
|                        |                   | Alkalinity Calibration Ver.   | 87.2      | % Recovery | 85          | 115         |
|                        |                   | Duplicate                     | 0.0       | R.P.D.     | 0           | 9           |
|                        |                   | Duplicate                     | 0.6       | R.P.D.     | 0           | 9           |
| Bicarbonate Alkalinity | HCO <sub>3</sub>  | Duplicate                     | 0.0       | R.P.D.     | 0           | 9           |
|                        |                   | Duplicate                     | 0.5       | R.P.D.     | 0           | 9           |
| Carbonate Alkalinity   | CO <sub>3</sub>   | Duplicate                     | NC        | R.P.D.     | 0           | 9           |
| Hydroxide Alkalinity   | OH                | Duplicate                     | NC        | R.P.D.     | 0           | 9           |
| Dissolved Fluoride     | F                 | Blank                         | < 0.05    | mg/L       | 0           | 0.05        |
|                        |                   | Dionex Certified Standard     | 103.9     | % Recovery | 90          | 110         |
|                        |                   | Duplicate                     | 0.0       | R.P.D.     | 0           | 10          |
|                        |                   | Duplicate                     | PASS      | R.P.D.     | 0           | 10          |

(Continued on next page)



REPORTED TO: Golder Associates Ltd.



REPORT DATE: February 22, 2006

GROUP NUMBER: 61230016

Batch Quality Control for Conventional Parameters in Water

| Parameter          |     | QC Type                   | QC Result | Units      | Lower Limit | Upper Limit |
|--------------------|-----|---------------------------|-----------|------------|-------------|-------------|
| Dissolved Chloride | Cl  | Blank                     | < 0.2     | mg/L       | 0           | 0.2         |
|                    |     | Dionex Certified Standard | 95.7      | % Recovery | 90          | 110         |
|                    |     | Duplicate                 | 2.8       | R.P.D.     | 0           | 12          |
|                    |     | Duplicate                 | PASS      | R.P.D.     | 0           | 12          |
| Dissolved Nitrate  | N   | Blank                     | < 0.05    | mg/L       | 0           | 0.05        |
|                    |     | Dionex Certified Standard | 96.9      | % Recovery | 90          | 110         |
|                    |     | Duplicate                 | 3.8       | R.P.D.     | 0           | 10          |
|                    |     | Duplicate                 | NC        | R.P.D.     | 0           | 10          |
| Nitrite            | N   | Blank                     | < 0.002   | mg/L       | 0           | 0.002       |
|                    |     | Spike                     | 102.0     | % Recovery | 86          | 112         |
|                    |     | Calibration Verification  | 102.5     | % Recovery | 93          | 107         |
|                    |     | Duplicate                 | NC        | R.P.D.     | 0           | 12          |
| Dissolved Sulphate | SO4 | Blank                     | < 0.5     | mg/L       | 0           | 0.5         |
|                    |     | Dionex Certified Standard | 92.7      | % Recovery | 90          | 110         |
|                    |     | Duplicate                 | 0.4       | R.P.D.     | 0           | 10          |
|                    |     | Duplicate                 | 0.5       | R.P.D.     | 0           | 10          |

uS/cm = microsiemens per centimeter

NTU = nephelometric turbidity units

< = Less than detection limit

R.P.D. = Relative Percent Difference

PASS = Duplicate sample results were in the range of one to five times the detection limit. R.P.D. calculation is not applicable in this range. Acceptance criteria is a maximum difference between the duplicates equivalent to the value of the detection limit.

NC = Not Calculated. Duplicate sample results were less than the detection limit. Relative Percent Difference calculation is not defined for analyte levels of less than detection limit.

CU = color units

mg/L = milligrams per liter





REPORTED TO: Golder Associates Ltd.



REPORT DATE: February 22, 2006

GROUP NUMBER: 61230016

Batch Quality Control for Total Metals Analysis in Water (QC# 74861)

| Parameter  | Duplicate<br>(R.P.D.)<br>512230301 | Duplicate<br>Limits | Duplicate<br>(R.P.D.)<br>512230324 | Duplicate<br>Limits | Spike (%<br>Recovery)<br>512230301 | Spike Limits |
|------------|------------------------------------|---------------------|------------------------------------|---------------------|------------------------------------|--------------|
| Mercury Hg | NC                                 | 20                  | NC                                 | 20                  | 105                                | 70 - 128     |

ug/L = micrograms per liter

R.P.D. = Relative Percent Difference

NC = Not Calculated. Duplicate sample results were less than the detection limit. Relative Percent Difference calculation is not defined for analyte levels of less than detection limit.





REPORTED TO: Golder Associates Ltd.



REPORT DATE: February 22, 2006

GROUP NUMBER: 61230016

---

**Batch Quality Control for Total Metals Analysis in Water (QC# 74861)**

| Parameter |    | Spike (%<br>Recovery)<br>512230324 | Spike Limits |
|-----------|----|------------------------------------|--------------|
| Mercury   | Hg | 105                                | 70 - 128     |

ug/L = micrograms per liter



REPORTED TO: Golder Associates Ltd.



REPORT DATE: February 22, 2006

GROUP NUMBER: 61230016

Batch Quality Control for Total Metals Analysis in Water (QC# 74869)

| Parameter |    | ICPMS Spike<br>(% Recovery)<br>512210235 | ICPMS Spike<br>Limits | ICPMS Lab<br>Fortified<br>Blank (%<br>Recovery) | ICPMS Lab<br>Fortified<br>Blank Limits | Total Blank<br>(mg/L) | Total Blank<br>Limits |
|-----------|----|------------------------------------------|-----------------------|-------------------------------------------------|----------------------------------------|-----------------------|-----------------------|
| Aluminum  | Al | -                                        | -                     | -                                               | -                                      | 0.009                 | 0.015                 |
| Antimony  | Sb | 89                                       | 78 - 118              | 85                                              | 75 - 117                               | < 0.0002              | 0.001                 |
| Arsenic   | As | 89                                       | 80 - 118              | 85                                              | 72 - 114                               | < 0.0002              | 0.001                 |
| Barium    | Ba | -                                        | -                     | 95                                              | 81 - 119                               | < 0.0002              | 0.001                 |
| Boron     | B  | -                                        | -                     | 100                                             | 92 - 110                               | -                     | -                     |
| Cadmium   | Cd | 87                                       | 74 - 124              | 87                                              | 78 - 116                               | < 0.00004             | 0.001                 |
| Chromium  | Cr | 91                                       | 70 - 130              | 95                                              | 83 - 119                               | < 0.0002              | 0.001                 |
| Copper    | Cu | 83                                       | 77 - 125              | 90                                              | 85 - 120                               | < 0.0002              | 0.001                 |
| Lead      | Pb | 90                                       | 77 - 124              | 85                                              | 80 - 116                               | < 0.0002              | 0.001                 |
| Manganese | Mn | 70                                       | 69 - 131              | 95                                              | 82 - 120                               | < 0.0002              | 0.001                 |
| Selenium  | Se | -                                        | -                     | 75                                              | 58 - 120                               | -                     | -                     |
| Uranium   | U  | 97                                       | 65 - 133              | 85                                              | 75 - 121                               | < 0.0001              | 0.0005                |
| Zinc      | Zn | -                                        | -                     | 100                                             | 64 - 126                               | < 0.001               | 0.01                  |

mg/L = milligrams per liter



REPORTED TO: Golder Associates Ltd.



REPORT DATE: February 22, 2006

GROUP NUMBER: 61230016

---

Instrument Quality Control for the PSA Mercury Analyzer-AF (QC# 149408)

QC Type: Calibration Verification

| Parameter |    | % Recovery | Limits   |
|-----------|----|------------|----------|
| Mercury   | Hg | 106        | 90 - 110 |



REPORTED TO: Golder Associates Ltd.



REPORT DATE: February 22, 2006

GROUP NUMBER: 61230016

---

**Batch Quality Control Frequency Summary**

Auto-Titrator Analysis (Batch# 74843)

| QC Type   | No. Samples |
|-----------|-------------|
| Blank     | 1           |
| Duplicate | 2           |

Mercury Water Bromination Prep (Batch# 74861)

| QC Type   | No. Samples |
|-----------|-------------|
| Duplicate | 4           |
| Spike     | 4           |

Turbidity Analysis (Batch# 74864)

| QC Type   | No. Samples |
|-----------|-------------|
| Blank     | 1           |
| Duplicate | 3           |

Colour Analysis (Batch# 74866)

| QC Type   | No. Samples |
|-----------|-------------|
| Blank     | 1           |
| Duplicate | 3           |

Total Metals Preparation (Batch# 74869)

| QC Type                   | No. Samples |
|---------------------------|-------------|
| ICPMS Spike               | 1           |
| ICP Spike Vista ICAP      | 1           |
| ICPMS Lab Fortified Blank | 1           |
| Total Blank               | 1           |
| Duplicate                 | 2           |

(Continued on next page)



REPORTED TO: Golder Associates Ltd.



REPORT DATE: February 22, 2006

GROUP NUMBER: 61230016

---

**Batch Quality Control Frequency Summary**

Water Lab Ion Chromatography (Batch# 74962)

| QC Type   | No. Samples |
|-----------|-------------|
| Blank     | 2           |
| Duplicate | 2           |

Coliform MF Method in Water (Batch# 74853)

| QC Type   | No. Samples |
|-----------|-------------|
| Blank     | 1           |
| Duplicate | 1           |

Auto-Titrator Analysis (Batch# 74843)

| QC Type    | No. Samples |
|------------|-------------|
| Batch Size | 25          |

Coliform MF Method in Water (Batch# 74853)

| QC Type    | No. Samples |
|------------|-------------|
| Batch Size | 6           |

Mercury Water Bromination Prep (Batch# 74861)

| QC Type    | No. Samples |
|------------|-------------|
| Batch Size | 37          |

(Continued on next page)



REPORTED TO: Golder Associates Ltd.



REPORT DATE: February 22, 2006

GROUP NUMBER: 61230016

---

#### Batch Quality Control Frequency Summary

##### Turbidity Analysis (Batch# 74864)

| QC Type    | No. Samples |
|------------|-------------|
| Batch Size | 31          |

##### Colour Analysis (Batch# 74866)

| QC Type    | No. Samples |
|------------|-------------|
| Batch Size | 28          |

##### Total Metals Preparation (Batch# 74869)

| QC Type    | No. Samples |
|------------|-------------|
| Batch Size | 32          |

##### Water Lab Ion Chromatography (Batch# 74962)

| QC Type    | No. Samples |
|------------|-------------|
| Batch Size | 22          |



## **SRC RESULTS**



## Foley, Jacqueline

---

**From:** SRC Analytical Laboratories [analytical@src.sk.ca]  
**Sent:** February 6, 2006 1:45 PM  
**To:** Foley, Jacqueline  
**Subject:** SRC Analytical Results for Group 2006-501

**Attachments:** 200600501.txt



200600501.txt  
(529 B)

Results for the following SRC Analytical Groups are included in the enclosed file:

2006-501

If you have any problems with your enclosed file, feel free to give me a call.

Mr. Loran Chrusch  
Computer Operations  
SRC Analytical Laboratories  
422 Downey Road  
Saskatoon, Saskatchewan  
S7N 4N1

Phone: (306) 933-7872  
Fax: (306) 933-7922  
email: chrusch@src.sk.ca

"SRC provides Smart Science Solutions"

This e-mail and any files transmitted with it are intended only for the named recipients and may contain legally privileged and/or confidential information. If you are not the intended recipient please do not disseminate, distribute or copy this e-mail without the consent of the sender.

| 200600501   |          |                                      |              |   |               |  |  |  |  |
|-------------|----------|--------------------------------------|--------------|---|---------------|--|--|--|--|
| SRC Group # | Sample # | Description                          | Analyte Name | < | Result        |  |  |  |  |
| Units       | Method   | Sample Type                          | DL           |   |               |  |  |  |  |
| 2006-501    | 1998     | 512300033 (PREV SRC GR# 85 LAB# 296) |              |   |               |  |  |  |  |
| 0.02        | Bq/L     | Pb 210, total                        | WATER 0.02   |   | Lead-210 1    |  |  |  |  |
| 2006-501    | 1998     | 512300033 (PREV SRC GR# 85 LAB# 296) |              |   |               |  |  |  |  |
| 0.01        | Bq/L     | Th 232, total                        | WATER 0.01   |   | Thorium-232 1 |  |  |  |  |

## **Appendix V**

### **Drillers Well Logs**








## **Appendix VI**

### **AQTESLOV**



### WELL TEST ANALYSIS

Data Set: N:\...\Report TW2 LH.aqt  
Date: 04/24/06

Time: 12:44:06

### PROJECT INFORMATION

Company: Golder Associates  
Client: Crystal Mt. Resort  
Project: 04-1440-116-2000  
Test Well: TW2  
Test Date: December 2005

### WELL DATA

#### Pumping Wells

| Well Name | X (m) | Y (m) |
|-----------|-------|-------|
| TW 2      | 0     | 0     |

#### Observation Wells

| Well Name | X (m) | Y (m) |
|-----------|-------|-------|
| □ TW2     | 0.1   | 0     |
| + TW1     | 0     | 15    |

### SOLUTION

Aquifer Model: Leaky

Solution Method: Hantush

T = 8.02 m<sup>2</sup>/day  
B/r = 0.0045 m<sup>-1</sup>  
b = 3.66 m

S = 6.398E-5  
Kz/Kr = 1.