

Overall Rating - High



This notification is intended as an informational bulletin for technical audiences.

Summary

The Vulnerability and Risk Management (VRM) Team is aware that Schneider Electric published security advisories to highlight a vulnerability in the following product:

- Easergy Studio – version 9.3.5 and prior

Technical Details

The Easergy Studio product is a software solution for configuring, monitoring, and managing control devices. Failure to apply the remediations provided below may risk an attacker with a user level account on the engineering workstation to escalate privileges which could result in an attacker gaining full control of the targeted workstation.

These vulnerabilities are rated as an overall **High** Severity.

Recommended Action

- Investigate how your area of responsibility is affected.
- Notify business owner(s) as required.
- *Ensure mitigation is performed at your next change window.*

Please notify [VRM](#) with any questions or concerns you may have.

References

- CVE-2023-7032
- [Schneider Electric Security Notification - SEVD-2024-009-02 \(PDF\)](#)
- [Schneider Electric Security Notifications](#)