

From: John Malinowski at Baldor-Marketing [mailto:JMalinowski@baldor.com]
Sent: Wednesday, December 10, 2008 上午 09:14
To: Ciccateri, Jim EMPR:EX
Cc: Roger H Daugherty
Subject: RE: FOR COMMENT - Regulatory Summary Proposal, 1-500hp electric motor efficiency standards under Energy Efficiency Act

Attached [Regulatory Summary for Premium Efficiency Motors 28Nov08_comments.doc] are our comments to this document. Much of the comments were made by Roger Daugherty, our representative and chair of the NEMA MG 1 technical committee.

The US EISA is written to be an amendment to the EAct92 and only sections that will replace old text are present. We think a more complete text is better as many people do not have easy access of the 1992 document and then one must evaluate what changed and what is still in affect. We feel that it is important to specifically mention IEC motors because equipment using non-compliant motors could easily be brought into the province or manufacturers could change the mounting of their motors to avoid compliance.

Please let me know if you have any questions.

John Malinowski
Product Manager AC & DC Motors
Baldor Electric Company
Phone 479-648-5909
Mobile 479-459-5909