

APPENDIX C - MOBILE AVIATION FUEL INSPECTION REPORT (CONT)

Meter Register

Make/Model _____
Last calibration date _____

Tagged with last calibration date Yes No
W and M approved Yes No
Temperature controlled metering Yes No

Comments: _____

Filtration and Product Tank

Make/Model _____

Single stage monitor aviation fuel filter Yes No Pre filter Yes No
Filter(s) marked/tagged (yearly change out date) Yes No Clause 4.14 Post filter (or nozzle sample) Yes No
Low points and ability to sample fuel Yes No Clause 5.24 Differential pressure gauges Yes No Clause 5.16.7
Post filter plumbing Steel Stainless Steel Aluminum NonFerrous Other
Product tank has low point drains (or ability to sample tank bottom) Yes No
Product tank Steel Stainless Steel Aluminum NonFerrous Epoxy Lined Other
Product tank has manifolds Yes No (product pipe goes direct to the internal)

If the filtration is coalescer/separator then it must qualify with EI1581 Cat C and M, and have S-L/W on the data plate. This confirms an ok for into plane with FSII (qualifies with EI 1581 5th Edition).

Static Bonding

Reel type Other Specify _____ Clause 5.12.4
75 ft with clamp Yes No Clause 5.17.3
150 ft with clamp (air side) Yes No Clause 5.19.3
Bonding system resistance tested (valid proof) Yes No Clause 5.26

Daily test if hot fuelling, otherwise weekly. Must not exceed 25 OHMs.

Fire Extinguishers

2 X 20 lb fire extinguishers with date tested tag Yes No Clause 6.2.2.1 20 BC rating Yes No
BC Purple K rating recommended Yes No Date tested by qualified contractor _____ Clause 5.17.1

Spill Kit

Minimum for 200 litres oil/fuel type Yes No Shovels Yes No
Sorbent pads (bundle) Yes No Gloves Yes No
Berm kit to contain spill Yes No Plug N Dike for emergency tank repair Yes No

Comments: _____

Mobile Fuelling Vehicle

Mobile radio programmed with road channels Yes No Handheld programmed with road channels Yes No
Mobile radio programmed with FLNRORD Yes No Handheld programmed with FLNRORD Yes No

Fuel Sample Kit (to meet regulation) Yes No

Last contained _____ Bio-fuel must have proof of steam cleaning

Pass Fail

Comments: _____

This inspection was reviewed with the operator by the following designated representative for the Ministry of Forests, Lands and Natural Resources Operations and Rural Development:

Inspector name _____ Signature _____ Date _____